Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

SA-1520260418

TEST REPORT

Report No.:	ME-1520260418	Date: 24.04.2026
ULR No.:	TC748726000008645F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No.1	Sample Quantity / Packing	Thimble: 1 X 1 No. SO_2:30 mL X 1 No. PVC Bottle NO_X:25 mL X 1 No. PVC Bottle
Date of Sampling	18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	As per method reference		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	24.04.2026

Stack Details	
Stack Identity	Boiler Unit No. 1
Stack attached to	ESP of Boiler Unit No. 1
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	169
Load at the time of monitoring (MW)	266
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Flue gas Temperature	^0C	120	-	IS 11255 (Part 3):2008
2.	Flue gas Velocity	m/s	28.3	-	IS 11255 (Part 3):2008
3.	Flue gas Flow Rate	Nm^3/h	1220093	-	IS 11255 (Part 3):2008
4.	Particulate Matter (PM)	mg/Nm^3	42	50	IS 11255 (Part 1):1985
5.	Sulphur Dioxide (SO_2)	mg/Nm^3	583	600	IS 11255 (Part 2):1985
6.	Oxides of Nitrogen (NO_X)	mg/Nm^3	217	450	IS 11255 (Part 7): 2005

END OF REPORT

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

SA-1520260418

TEST REPORT

Report No.:	ME-1520260418	Date: 24.04.2026
ULR No.:	TC748726000008645F	

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. #: Limit as per MPCB Consent
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

SA-1520260418

TEST REPORT

Report No.:	ME-1520260418N	Date: 24.04.2026
ULR No.:	-	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No.1	Sample Quantity / Packing	CO: 1L X 1 No. Gas Bladder
Date of Sampling	18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	As per method reference		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	24.04.2026

Stack Details	
Stack Identity	Boiler Unit No. 1
Stack attached to	ESP of Boiler Unit No. 1
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	169
Load at the time of monitoring (MW)	266
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Carbon Monoxide (CO)	mg/Nm^3	45	-	IS 5182 (Part 10): 1999 (NDIR method)

END OF REPORT

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. The result listed refers only to the tested sample(s) and applicable parameter(s).
4. This report is not to be reproduced except in full, without the written approval of the laboratory.
5. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

SA-1521260418

TEST REPORT

Report No.:	ME-1521260418	Date: 24.04.2026
ULR No.:	TC748726000008646F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No.3	Sample Quantity / Packing	Thimble: 1 X 1 No. SO_2:30 mL X 1 No. PVC Bottle NO_X:25 mL X 1 No. PVC Bottle
Date of Sampling	18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	As per method reference		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	24.04.2026

Stack Details	
Stack Identity	Boiler Unit No. 3
Stack attached to	ESP of Boiler Unit No. 3
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	168
Load at the time of monitoring (MW)	265
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Flue gas Temperature	^0C	118	-	IS 11255 (Part 3):2008
2.	Flue gas Velocity	m/s	29.0	-	IS 11255 (Part 3):2008
3.	Flue gas Flow Rate	Nm^3/h	1256306	-	IS 11255 (Part 3):2008
4.	Particulate Matter (PM)	mg/Nm^3	41	50	IS 11255 (Part 1):1985
5.	Sulphur Dioxide (SO_2)	mg/Nm^3	533	600	IS 11255 (Part 2):1985
6.	Oxides of Nitrogen (NO_X)	mg/Nm^3	274	450	IS 11255 (Part 7): 2005

END OF REPORT

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

SA-1521260418

TEST REPORT

Report No.:	ME-1521260418	Date: 24.04.2026
ULR No.:	TC748726000008646F	

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. #: Limit as per MPCB Consent
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

SA-1521260418

TEST REPORT

Report No.:	ME-1521260418N	Date: 24.04.2026
ULR No.:	-	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No.3	Sample Quantity / Packing	CO: 1L X 1 No. Gas Bladder
Date of Sampling	18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	As per method reference		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	24.04.2026

Stack Details	
Stack Identity	Boiler Unit No. 3
Stack attached to	ESP of Boiler Unit No. 3
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	168
Load at the time of monitoring (MW)	265
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Carbon Monoxide (CO)	mg/Nm^3	34	-	IS 5182 (Part 10): 1999 (NDIR method)

END OF REPORT

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. The result listed refers only to the tested sample(s) and applicable parameter(s).
4. This report is not to be reproduced except in full, without the written approval of the laboratory.
5. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

MEEP

MAHABAL ENVIRO ENGINEERS P.LTD. Laboratory Division

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

SA-1522260418

TEST REPORT

Report No.:	ME-1522260418	Date: 24.04.2026
ULR No.:	TC748726000008647F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No.4	Sample Quantity / Packing	Thimble: 1 X 1 No. SO_2:30 mL X 1 No. PVC Bottle NO_X:25 mL X 1 No. PVC Bottle
Date of Sampling	18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	As per method reference		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	24.04.2026

Stack Details	
Stack Identity	Boiler Unit No. 4
Stack attached to	ESP of Boiler Unit No. 4
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	160
Load at the time of monitoring (MW)	270
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Flue gas Temperature	°C	123	-	IS 11255 (Part 3):2008
2.	Flue gas Velocity	m/s	28.2	-	IS 11255 (Part 3):2008
3.	Flue gas Flow Rate	Nm^3/h	1207209	-	IS 11255 (Part 3):2008
4.	Particulate Matter (PM)	mg/Nm^3	38	50	IS 11255 (Part 1):1985
5.	Sulphur Dioxide (SO_2)	mg/Nm^3	547	600	IS 11255 (Part 2):1985
6.	Oxides of Nitrogen (NO_X)	mg/Nm^3	218	450	IS 11255 (Part 7): 2005

END OF REPORT

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

SA-1522260418

TEST REPORT

Report No.:	ME-1522260418	Date: 24.04.2026
ULR No.:	TC748726000008647F	

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. #: Limit as per MPCB Consent
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and
authorised by

Harish Mendhi
Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

SA-1522260418

TEST REPORT

Report No.:	ME-1522260418N	Date: 24.04.2026
ULR No.:	-	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No.4	Sample Quantity / Packing	CO: 1L X 1 No. Gas Bladder
Date of Sampling	18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	As per method reference		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	24.04.2026

Stack Details	
Stack Identity	Boiler Unit No. 4
Stack attached to	ESP of Boiler Unit No. 4
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	160
Load at the time of monitoring (MW)	270
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Carbon Monoxide (CO)	mg/Nm^3	27	-	IS 5182 (Part 10): 1999 (NDIR method)

END OF REPORT

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. The result listed refers only to the tested sample(s) and applicable parameter(s).
4. This report is not to be reproduced except in full, without the written approval of the laboratory.
5. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

MEEPL

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

SA-1523260418

TEST REPORT

Report No.:	ME-1523260418	Date: 24.04.2026
ULR No.:	TC748726000008648F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No.5	Sample Quantity / Packing	Thimble: 1 X 1 No. SO_2:30 mL X 1 No. PVC Bottle NO_X:25 mL X 1 No. PVC Bottle
Date of Sampling	18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	As per method reference		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	24.04.2026

Stack Details	
Stack Identity	Boiler Unit No. 5
Stack attached to	ESP of Boiler Unit No. 5
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	160
Load at the time of monitoring (MW)	270
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Flue gas Temperature	^0C	115	-	IS 11255 (Part 3):2008
2.	Flue gas Velocity	m/s	28.8	-	IS 11255 (Part 3):2008
3.	Flue gas Flow Rate	Nm^3/h	1258315	-	IS 11255 (Part 3):2008
4.	Particulate Matter (PM)	mg/Nm^3	44	50	IS 11255 (Part 1):1985
5.	Sulphur Dioxide (SO_2)	mg/Nm^3	598	600	IS 11255 (Part 2):1985
6.	Oxides of Nitrogen (NO_X)	mg/Nm^3	234	450	IS 11255 (Part 7): 2005

END OF REPORT

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

SA-1523260418

TEST REPORT

Report No.:	ME-1523260418	Date: 24.04.2026
ULR No.:	TC748726000008648F	

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. #: Limit as per MPCB Consent
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and
authorised by

Harish Mendhi
Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

SA-1523260418

TEST REPORT

Report No.:	ME-1523260418N	Date: 24.04.2026
ULR No.:	-	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No.5	Sample Quantity / Packing	CO: 1L X 1 No. Gas Bladder
Date of Sampling	18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	As per method reference		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	24.04.2026

Stack Details	
Stack Identity	Boiler Unit No. 5
Stack attached to	ESP of Boiler Unit No. 5
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	160
Load at the time of monitoring (MW)	270
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Carbon Monoxide (CO)	mg/Nm^3	29	-	IS 5182 (Part 10): 1999 (NDIR method)

END OF REPORT

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. The result listed refers only to the tested sample(s) and applicable parameter(s).
4. This report is not to be reproduced except in full, without the written approval of the laboratory.
5. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1516260418

Report No.:	ME-1516260418	Date: 25.04.2026
ULR No.:	TC748726000008695F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ambient Air	Sampling Done by	Laboratory
Sampling Location	Village Kapustalni	Sample Quantity / Packing	PM_{10}, B(a), Ni, As, Pb: Filter Paper 1 X 3 No. $PM_{2.5}$: Filter Paper 1 X 1 No. SO_2:30 mL X 6 No. PVC Bottle NO_2:30 mL X 6 No. PVC Bottle NH_3:10 mL X 24 No. PVC Bottle O_3:10 mL X 24 No. PVC Bottle Charcoal Tubes: 1 X 6 No. CO:2L X 3No. Gas Bladder
Date of Sampling	17.04.2026 to 18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	As per method reference		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	25.04.2026

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Ambient Air)				
1.	Sulphur Dioxide (SO_2)	µg/m³	11.3	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
2.	Nitrogen Dioxide (NO_2)	µg/m³	15.8	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
3.	Particulate Matter (size less than 10µm) or PM_{10}	µg/m³	82	100	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
4.	Particulate Matter (size less than 2.5µm) or $PM_{2.5}$	µg/m³	34	60	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
5.	Ozone (O_3)	µg/m³	21.2	180	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
6.	Lead (as Pb)	µg/m³	BQL (LOQ:0.02)	01	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1516260418

Report No.:	ME-1516260418	Date: 25.04.2026
ULR No.:	TC748726000008695F	

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
7.	Carbon Monoxide (CO)	mg/m^3	1.05	04	CPCB Guidelines for the Measurement of Ambient Air Pollutants Volume-II, 2012-13 (NDIR method)
8.	Ammonia (NH_3)	$\mu g/m^3$	BQL (LOQ:20)	400	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
9.	Benzene (C_6H_6)	$\mu g/m^3$	BQL (LOQ:1)	05	IS 5182 (Part 11): 2006
10.	Benzo(a)Pyrene (Particulate phase only)	ng/m^3	BQL (LOQ:0.5)	01	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
11.	Arsenic (as As)	ng/m^3	BQL (LOQ:0.3)	06	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
12.	Nickel (as Ni)	ng/m^3	BQL (LOQ:3)	20	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. TWA: Time Weighted Average
4. Duration of Sampling: 24 h
5. NAAQS: National Ambient Air Quality Standard
6. #- NAAQS specified as: 24 h. TWA in case of Sulphur Dioxide, Nitrogen Dioxide, PM_{10}, $PM_{2.5}$, Lead and Ammonia; 1 h. TWA in case of Carbon Monoxide, Ozone; Annual TWA in case of Benzene, Benzo (a) Pyrene, Arsenic and Nickel.
7. The result listed refers only to the tested sample(s) and applicable parameter(s).
8. This report is not to be reproduced except in full, without the written approval of the laboratory.
9. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1517260418

Report No.:	ME-1517260418	Date: 25.04.2026
ULR No.:	TC748726000008696F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ambient Air	Sampling Done by	Laboratory
Sampling Location	Village Dawargaon	Sample Quantity / Packing	PM_{10}, B(a), Ni, As, Pb: Filter Paper 1 X 3 No. $PM_{2.5}$: Filter Paper 1 X 1 No. SO_2:30 mL X 6 No. PVC Bottle NO_2:30 mL X 6 No. PVC Bottle NH_3:10 mL X 24 No. PVC Bottle O_3:10 mL X 24 No. PVC Bottle Charcoal Tubes: 1 X 6 No. CO:2L X 3No. Gas Bladder
Date of Sampling	17.04.2026 to 18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	As per method reference		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	25.04.2026

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Ambient Air)				
1.	Sulphur Dioxide (SO_2)	µg/m³	13.4	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
2.	Nitrogen Dioxide (NO_2)	µg/m³	18.9	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
3.	Particulate Matter (size less than 10µm) or PM_{10}	µg/m³	74	100	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
4.	Particulate Matter (size less than 2.5µm) or $PM_{2.5}$	µg/m³	26	60	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
5.	Ozone (O_3)	µg/m³	BQL (LOQ:19.6)	180	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
6.	Lead (as Pb)	µg/m³	BQL (LOQ:0.02)	01	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1517260418

Report No.:	ME-1517260418	Date: 25.04.2026
ULR No.:	TC748726000008696F	

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
7.	Carbon Monoxide (CO)	mg/m^3	0.74	04	CPCB Guidelines for the Measurement of Ambient Air Pollutants Volume-II, 2012-13 (NDIR method)
8.	Ammonia (NH_3)	$\mu g/m^3$	22.5	400	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
9.	Benzene (C_6H_6)	$\mu g/m^3$	BQL (LOQ:1)	05	IS 5182 (Part 11): 2006
10.	Benzo(a)Pyrene (Particulate phase only)	ng/m^3	BQL (LOQ:0.5)	01	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
11.	Arsenic (as As)	ng/m^3	BQL (LOQ:0.3)	06	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
12.	Nickel (as Ni)	ng/m^3	3.13	20	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. TWA: Time Weighted Average
4. Duration of Sampling: 24 h
5. NAAQS: National Ambient Air Quality Standard
6. #- NAAQS specified as: 24 h. TWA in case of Sulphur Dioxide, Nitrogen Dioxide, PM_{10}, $PM_{2.5}$, Lead and Ammonia; 1 h. TWA in case of Carbon Monoxide, Ozone; Annual TWA in case of Benzene, Benzo (a) Pyrene, Arsenic and Nickel.
7. The result listed refers only to the tested sample(s) and applicable parameter(s).
8. This report is not to be reproduced except in full, without the written approval of the laboratory.
9. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1518260418

Report No.:	ME-1518260418	Date: 25.04.2026
ULR No.:	TC748726000008697F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ambient Air	Sampling Done by	Laboratory
Sampling Location	Village Wagholi Gate	Sample Quantity / Packing	PM_{10}, B(a), Ni, As, Pb: Filter Paper 1 X 3 No. $PM_{2.5}$: Filter Paper 1 X 1 No. SO_2:30 mL X 6 No. PVC Bottle NO_2:30 mL X 6 No. PVC Bottle NH_3:10 mL X 24 No. PVC Bottle O_3:10 mL X 24 No. PVC Bottle Charcoal Tubes: 1 X 6 No. CO:2L X 3No. Gas Bladder
Date of Sampling	17.04.2026 to 18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	As per method reference		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	25.04.2026

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Ambient Air)				
1.	Sulphur Dioxide (SO_2)	µg/m³	12.9	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
2.	Nitrogen Dioxide (NO_2)	µg/m³	17.5	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
3.	Particulate Matter (size less than 10µm) or PM_{10}	µg/m³	86	100	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
4.	Particulate Matter (size less than 2.5µm) or $PM_{2.5}$	µg/m³	21	60	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
5.	Ozone (O_3)	µg/m³	BQL (LOQ:19.6)	180	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
6.	Lead (as Pb)	µg/m³	BQL (LOQ:0.02)	01	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1518260418

Report No.:	ME-1518260418	Date: 25.04.2026
ULR No.:	TC748726000008697F	

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
7.	Carbon Monoxide (CO)	mg/m^3	0.88	04	CPCB Guidelines for the Measurement of Ambient Air Pollutants Volume-II, 2012-13 (NDIR method)
8.	Ammonia (NH_3)	$\mu g/m^3$	21.6	400	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
9.	Benzene (C_6H_6)	$\mu g/m^3$	BQL (LOQ:1)	05	IS 5182 (Part 11): 2006
10.	Benzo(a)Pyrene (Particulate phase only)	ng/m^3	BQL (LOQ:0.5)	01	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
11.	Arsenic (as As)	ng/m^3	BQL (LOQ:0.3)	06	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
12.	Nickel (as Ni)	ng/m^3	BQL (LOQ:3)	20	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. TWA: Time Weighted Average
4. Duration of Sampling: 24 h
5. NAAQS: National Ambient Air Quality Standard
6. #- NAAQS specified as: 24 h. TWA in case of Sulphur Dioxide, Nitrogen Dioxide, PM_{10}, $PM_{2.5}$, Lead and Ammonia; 1 h. TWA in case of Carbon Monoxide, Ozone; Annual TWA in case of Benzene, Benzo (a) Pyrene, Arsenic and Nickel.
7. The result listed refers only to the tested sample(s) and applicable parameter(s).
8. This report is not to be reproduced except in full, without the written approval of the laboratory.
9. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1519260418

Report No.:	ME-1519260418	Date: 25.04.2026
ULR No.:	TC748726000008698F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ambient Air	Sampling Done by	Laboratory
Sampling Location	Terrace of Bachelor Guest House	Sample Quantity / Packing	PM_{10}, B(a), Ni, As, Pb: Filter Paper 1 X 3 No. $PM_{2.5}$: Filter Paper 1 X 1 No. SO_2:30 mL X 6 No. PVC Bottle NO_2:30 mL X 6 No. PVC Bottle NH_3:10 mL X 24 No. PVC Bottle O_3:10 mL X 24 No. PVC Bottle Charcoal Tubes: 1 X 6 No. CO:2L X 3No. Gas Bladder
Date of Sampling	17.04.2026 to 18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	As per method reference		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	25.04.2026

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Ambient Air)				
1.	Sulphur Dioxide (SO_2)	µg/m³	16.1	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
2.	Nitrogen Dioxide (NO_2)	µg/m³	20.5	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
3.	Particulate Matter (size less than 10µm) or PM_{10}	µg/m³	91	100	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
4.	Particulate Matter (size less than 2.5µm) or $PM_{2.5}$	µg/m³	32	60	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
5.	Ozone (O_3)	µg/m³	21.6	180	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
6.	Lead (as Pb)	µg/m³	BQL (LOQ:0.02)	01	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1519260418

Report No.:	ME-1519260418	Date: 25.04.2026
ULR No.:	TC748726000008698F	

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
7.	Carbon Monoxide (CO)	mg/m^3	0.72	04	CPCB Guidelines for the Measurement of Ambient Air Pollutants Volume-II, 2012-13 (NDIR method)
8.	Ammonia (NH_3)	$\mu g/m^3$	23.5	400	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
9.	Benzene (C_6H_6)	$\mu g/m^3$	BQL (LOQ:1)	05	IS 5182 (Part 11): 2006
10.	Benzo(a)Pyrene (Particulate phase only)	ng/m^3	BQL (LOQ:0.5)	01	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
11.	Arsenic (as As)	ng/m^3	BQL (LOQ:0.3)	06	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13
12.	Nickel (as Ni)	ng/m^3	3.17	20	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. TWA: Time Weighted Average
4. Duration of Sampling: 24 h
5. NAAQS: National Ambient Air Quality Standard
6. #- NAAQS specified as: 24 h. TWA in case of Sulphur Dioxide, Nitrogen Dioxide, PM_{10}, $PM_{2.5}$, Lead and Ammonia; 1 h. TWA in case of Carbon Monoxide, Ozone; Annual TWA in case of Benzene, Benzo (a) Pyrene, Arsenic and Nickel.
7. The result listed refers only to the tested sample(s) and applicable parameter(s).
8. This report is not to be reproduced except in full, without the written approval of the laboratory.
9. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

MEEPL

MAHABAL ENVIRO ENGINEERS P.LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

ANA-1524260418

Report No.:	ME-1524260418	Date: 21.04.2026
ULR No.:	TC748726000008235F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**	SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Workroom Noise	
Date of Sampling	17.04.2026	
Sampling Procedure	CPCB Protocol for Ambient level Noise Monitoring 2015	

Sr. No.	Location	Time in h	Sound Level L_{eq} dB (A)	
			L_{min}	L_{max}
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Workroom Noise)			
1.	Turbine Area No. 3 & 4	14:10 to 14:15	65.6	69.3
2.	Near CHP Crusher House	14:30 to 14:35	62.1	67.2
3.	Near Compressor Room	14:45 to 14:50	64.2	68.4
4.	Near Main Gate	11:00 to 11:05	58.5	63.8
5.	Near Colony	11:35 to 11:40	54.9	61.8

Limit as per The Factories Act, 1948, The Maharashtra Factory Rules, 1963, Schedule XXIV	
Total time of exposure per day, in hours.	**Max. Sound pressure level in dB (A)**
8	90
6	92
4	95
3	97
2	100
1 ½	102
1	105
¾	107
½	110
¼	115

END OF REPORT

Note:
1. The result listed refers only to the tested sample(s) and applicable parameter(s).
2. This report is not to be reproduced except in full, without the written approval of the laboratory.
3. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

SW-1525260418

TEST REPORT

Report No.:	ME-1525260418	Date: 25.04.2026
ULR No.:	TC748726000008699F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Surface water	Sampling Done by	Laboratory
Sampling Location	Wagholi Pond	Sample Quantity / Packing	2L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	25.04.2026

Sr. No.	Parameter	Unit	Result	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Surface Water)			
1.	Colour	Hazen	BQL (LOQ:1)	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.4	APHA 24th Ed. 2023, 2130-B
4.	pH (at 25°C)	-	7.8	APHA 24th Ed. 2023, 4500-H+-B
5.	Residual Chlorine (Free)	mg/L	BQL (LOQ:0.05)	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids (at 180°C)	mg/L	772	IS 3025 (Part 16):2023
7.	Total Suspended Solids (at 105°C)	mg/L	7	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	340	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	608	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	110	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	147	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	4.39	APHA 24th Ed. 2023,4500-NO_3, E
13.	Calcium (as Ca)	mg/L	117	APHA 24th Ed. 2023, 3500-Ca-B
14.	Magnesium (as Mg)	mg/L	76.8	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.34	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.3	APHA 24th Ed. 2023, 4500-O, B & C

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

SW-1525260418

TEST REPORT

Report No.:	ME-1525260418	Date: 25.04.2026
ULR No.:	TC748726000008699F	

Sr. No.	Parameter	Unit	Result	Method Reference
17.	Oil and Grease	mg/L	BQL (LOQ:1)	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water			
20.	Boron (as B)	mg/L	BQL (LOQ:0.02)	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.580	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	0.030	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	0.022	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. The result listed refers only to the tested sample(s) and applicable parameter(s).
4. This report is not to be reproduced except in full, without the written approval of the laboratory.
5. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

MEEPL

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

SW-1526260418

TEST REPORT

Report No.:	ME-1526260418	Date: 25.04.2026
ULR No.:	TC748726000008700F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Surface water	Sampling Done by	Laboratory
Sampling Location	Malegaon Pond	Sample Quantity / Packing	2L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	25.04.2026

Sr. No.	Parameter	Unit	Result	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Surface Water)			
1.	Colour	Hazen	BQL (LOQ:1)	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.3	APHA 24th Ed. 2023, 2130-B
4.	pH (at 25°C)	-	7.9	APHA 24th Ed. 2023, 4500-H+-B
5.	Residual Chlorine (Free)	mg/L	BQL (LOQ:0.05)	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids (at 180°C)	mg/L	793	IS 3025 (Part 16):2023
7.	Total Suspended Solids (at 105°C)	mg/L	BQL (LOQ:5)	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	354	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	600	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	110	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	148	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	3.90	APHA 24th Ed. 2023,4500-NO_3, E
13.	Calcium (as Ca)	mg/L	114	APHA 24th Ed. 2023, 3500-Ca-B
14.	Magnesium (as Mg)	mg/L	76.8	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.33	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.0	APHA 24th Ed. 2023, 4500-O, B & C

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

SW-1526260418

TEST REPORT

Report No.:	ME-1526260418	Date: 25.04.2026
ULR No.:	TC748726000008700F	

Sr. No.	Parameter	Unit	Result	Method Reference
17.	Oil and Grease	mg/L	BQL (LOQ:1)	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water			
20.	Boron (as B)	mg/L	BQL (LOQ:0.02)	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.120	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	0.016	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	BQL (LOQ:0.02)	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. The result listed refers only to the tested sample(s) and applicable parameter(s).
4. This report is not to be reproduced except in full, without the written approval of the laboratory.
5. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

MEEPL

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

GW-1527260418

TEST REPORT

Report No.:	ME-1527260418	Date: 25.04.2026
ULR No.:	TC748726000008701F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ground water	Sampling Done by	Laboratory
Sampling Location	Village Kapustalni	Sample Quantity / Packing	3L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	25.04.2026

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Ground Water)					
1.	Colour	Hazen	BQL (LOQ:1)	5 Max.	15 Max.	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.2	1 Max.	5 Max.	APHA 24th Ed. 2023, 2130-B
4.	pH (at 25°C)	-	7.3	6.5 to 8.5	No relaxation	APHA 24th Ed. 2023, 4500-H+-B
5.	Residual Chlorine (Free)	mg/L	BQL (LOQ:0.05)	0.2 Min.	1.0 Min.	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids (at 180°C)	mg/L	521	500 Max.	2000 Max.	IS 3025 (Part 16):2023
7.	Total Suspended Solids (at 105°C)	mg/L	BQL (LOQ:5)	-	-	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	310	200 Max.	600 Max.	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	392	200 Max.	600 Max.	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	38.0	250 Max.	1000 Max.	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	41.2	200 Max.	400 Max.	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	42.2	45 Max.	No relaxation	APHA 24th Ed. 2023,4500-NO_3, B
13.	Calcium (as Ca)	mg/L	84.1	75 Max.	200 Max.	APHA 24th Ed. 2023, 3500-Ca-B

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

GW-1527260418

TEST REPORT

Report No.:	ME-1527260418	Date: 25.04.2026
ULR No.:	TC748726000008701F	

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
14.	Magnesium (as Mg)	mg/L	44.2	30 Max.	100 Max.	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.22	1 Max.	1.5 Max.	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.2	-	-	APHA 24th Ed. 2023, 4500-O, B & C
17.	Oil and Grease	mg/L	BQL (LOQ:1)	-	-	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	0.05 Max.	No relaxation	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	0.001 Max.	0.002 Max.	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water					
20.	Boron (as B)	mg/L	BQL(LOQ:0.02)	0.5 Max.	2.4 Max.	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.103	1.0 Max.	No relaxation	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	0.016	0.1 Max.	0.3 Max.	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	0.03 Max.	0.2 Max.	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	0.003Max	No relaxation	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	0.05 Max.	No relaxation	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	0.05 Max.	1.5 Max.	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	BQL (LOQ:0.02)	5 Max.	15 Max.	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	0.001Max	No relaxation	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. # Acceptable Limit as per IS 10500:2012
4. $ Permissible Limit in the Absence of Alternate Source as per IS 10500:2012
5. The result listed refers only to the tested sample(s) and applicable parameter(s).
6. This report is not to be reproduced except in full, without the written approval of the laboratory.
7. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1530260418

Report No.:	ME-1530260418	Date: 25.04.2026
ULR No.:	TC748726000008704F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ground water	Sampling Done by	Laboratory
Sampling Location	Borewell Water Village-Digargaon	Sample Quantity / Packing	3L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	25.04.2026

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Ground Water)					
1.	Colour	Hazen	BQL (LOQ:1)	5 Max.	15 Max.	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.3	1 Max.	5 Max.	APHA 24th Ed. 2023, 2130-B
4.	pH (at 25°C)	-	7.4	6.5 to 8.5	No relaxation	APHA 24th Ed. 2023, 4500-H+-B
5.	Residual Chlorine (Free)	mg/L	BQL (LOQ:0.05)	0.2 Min.	1.0 Min.	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids (at 180°C)	mg/L	702	500 Max.	2000 Max.	IS 3025 (Part 16):2023
7.	Total Suspended Solids (at 105°C)	mg/L	BQL (LOQ:5)	-	-	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	306	200 Max.	600 Max.	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	524	200 Max.	600 Max.	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	132	250 Max.	1000 Max.	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	52.0	200 Max.	400 Max.	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	25.4	45 Max.	No relaxation	APHA 24th Ed. 2023,4500-NO_3, B
13.	Calcium (as Ca)	mg/L	128	75 Max.	200 Max.	APHA 24th Ed. 2023, 3500-Ca-B

Reviewed and authorised by

Kishor Yeole
Vice President
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1530260418

Report No.:	ME-1530260418	Date: 25.04.2026
ULR No.:	TC748726000008704F	

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
14.	Magnesium (as Mg)	mg/L	49.6	30 Max.	100 Max.	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.25	1 Max.	1.5 Max.	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.4	-	-	APHA 24th Ed. 2023, 4500-O, B & C
17.	Oil and Grease	mg/L	BQL (LOQ:1)	-	-	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	0.05 Max.	No relaxation	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	0.001 Max.	0.002 Max.	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water					
20.	Boron (as B)	mg/L	BQL (LOQ:0.02)	0.5 Max.	2.4 Max.	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.097	1.0 Max.	No relaxation	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	BQL (LOQ:0.01)	0.1 Max.	0.3 Max.	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	0.03 Max.	0.2 Max.	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	0.003Max	No relaxation	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	0.05 Max.	No relaxation	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	0.05 Max.	1.5 Max.	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	0.022	5 Max.	15 Max.	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	0.001Max	No relaxation	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. # Acceptable Limit as per IS 10500:2012
4. $ Permissible Limit in the Absence of Alternate Source as per IS 10500:2012
5. The result listed refers only to the tested sample(s) and applicable parameter(s).
6. This report is not to be reproduced except in full, without the written approval of the laboratory.
7. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Kishor Yeole
Vice President
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

GW-1528260418

TEST REPORT

Report No.:	ME-1528260418	Date: 25.04.2026
ULR No.:	TC748726000008702F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ground water	Sampling Done by	Laboratory
Sampling Location	Village Pimpalvihirgaon	Sample Quantity / Packing	3L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	25.04.2026

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Ground Water)					
1.	Colour	Hazen	BQL (LOQ:1)	5 Max.	15 Max.	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.3	1 Max.	5 Max.	APHA 24th Ed. 2023, 2130-B
4.	pH (at 25°C)	-	7.0	6.5 to 8.5	No relaxation	APHA 24th Ed. 2023, 4500-H+-B
5.	Residual Chlorine (Free)	mg/L	BQL (LOQ:0.05)	0.2 Min.	1.0 Min.	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids (at 180°C)	mg/L	522	500 Max.	2000 Max.	IS 3025 (Part 16):2023
7.	Total Suspended Solids (at 105°C)	mg/L	BQL (LOQ:5)	-	-	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	312	200 Max.	600 Max.	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	388	200 Max.	600 Max.	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	37.0	250 Max.	1000 Max.	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	42.4	200 Max.	400 Max.	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	42.4	45 Max.	No relaxation	APHA 24th Ed. 2023,4500-NO_3, B
13.	Calcium (as Ca)	mg/L	87.4	75 Max.	200 Max.	APHA 24th Ed. 2023, 3500-Ca-B

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

GW-1528260418

TEST REPORT

Report No.:	ME-1528260418	Date: 25.04.2026
ULR No.:	TC748726000008702F	

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
14.	Magnesium (as Mg)	mg/L	41.3	30 Max.	100 Max.	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.19	1 Max.	1.5 Max.	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.2	-	-	APHA 24th Ed. 2023, 4500-O, B & C
17.	Oil and Grease	mg/L	BQL (LOQ:1)	-	-	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	0.05 Max.	No relaxation	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	0.001 Max.	0.002 Max.	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water					
20.	Boron (as B)	mg/L	BQL (LOQ:0.02)	0.5 Max.	2.4 Max.	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.076	1.0 Max.	No relaxation	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	BQL (LOQ:0.01)	0.1 Max.	0.3 Max.	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	0.03 Max.	0.2 Max.	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	0.003Max	No relaxation	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	0.05 Max.	No relaxation	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	0.05 Max.	1.5 Max.	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	BQL (LOQ:0.02)	5 Max.	15 Max.	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	0.001Max	No relaxation	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. # Acceptable Limit as per IS 10500:2012
4. $ Permissible Limit in the Absence of Alternate Source as per IS 10500:2012
5. The result listed refers only to the tested sample(s) and applicable parameter(s).
6. This report is not to be reproduced except in full, without the written approval of the laboratory.
7. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

GW-1529260418

TEST REPORT

Report No.:	ME-1529260418	Date: 25.04.2026
ULR No.:	TC748726000008703F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ground water	Sampling Done by	Laboratory
Sampling Location	Village-Talkhanda	Sample Quantity / Packing	3L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	25.04.2026

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Ground Water)					
1.	Colour	Hazen	BQL (LOQ:1)	5 Max.	15 Max.	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.2	1 Max.	5 Max.	APHA 24th Ed. 2023, 2130-B
4.	pH (at 25°C)	-	7.3	6.5 to 8.5	No relaxation	APHA 24th Ed. 2023, 4500-H+-B
5.	Residual Chlorine (Free)	mg/L	BQL (LOQ:0.05)	0.2 Min.	1.0 Min.	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids (at 180°C)	mg/L	523	500 Max.	2000 Max.	IS 3025 (Part 16):2023
7.	Total Suspended Solids (at 105°C)	mg/L	BQL (LOQ:5)	-	-	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	308	200 Max.	600 Max.	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	386	200 Max.	600 Max.	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	39.0	250 Max.	1000 Max.	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	41.8	200 Max.	400 Max.	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	41.9	45 Max.	No relaxation	APHA 24th Ed. 2023,4500-NO_3, B
13.	Calcium (as Ca)	mg/L	86.6	75 Max.	200 Max.	APHA 24th Ed. 2023, 3500-Ca-B

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

GW-1529260418

TEST REPORT

Report No.:	ME-1529260418	Date: 25.04.2026
ULR No.:	TC748726000008703F	

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
14.	Magnesium (as Mg)	mg/L	41.3	30 Max.	100 Max.	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.23	1 Max.	1.5 Max.	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.4	-	-	APHA 24th Ed. 2023, 4500-O, B & C
17.	Oil and Grease	mg/L	BQL (LOQ:1)	-	-	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	0.05 Max.	No relaxation	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	0.001 Max.	0.002 Max.	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water					
20.	Boron (as B)	mg/L	BQL (LOQ:0.02)	0.5 Max.	2.4 Max.	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.309	1.0 Max.	No relaxation	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	0.010	0.1 Max.	0.3 Max.	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	0.03 Max.	0.2 Max.	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	0.003Max	No relaxation	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	0.05 Max.	No relaxation	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	0.05 Max.	1.5 Max.	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	BQL (LOQ:0.02)	5 Max.	15 Max.	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	0.001Max	No relaxation	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. # Acceptable Limit as per IS 10500:2012
4. $ Permissible Limit in the Absence of Alternate Source as per IS 10500:2012
5. The result listed refers only to the tested sample(s) and applicable parameter(s).
6. This report is not to be reproduced except in full, without the written approval of the laboratory.
7. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

GW-1531260418

TEST REPORT

Report No.:	ME-1531260418	Date: 25.04.2026
ULR No.:	TC748726000008705F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ground water	Sampling Done by	Laboratory
Sampling Location	Well Water Backside of Ash Dyke Area Mr. Narayan Lomte Farm	Sample Quantity / Packing	3L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	25.04.2026

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Ground Water)					
1.	Colour	Hazen	BQL (LOQ:1)	5 Max.	15 Max.	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.2	1 Max.	5 Max.	APHA 24th Ed. 2023, 2130-B
4.	pH (at 25°C)	-	7.3	6.5 to 8.5	No relaxation	APHA 24th Ed. 2023, 4500-H+-B
5.	Residual Chlorine (Free)	mg/L	BQL (LOQ:0.05)	0.2 Min.	1.0 Min.	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids (at 180°C)	mg/L	518	500 Max.	2000 Max.	IS 3025 (Part 16):2023
7.	Total Suspended Solids (at 105°C)	mg/L	BQL (LOQ:5)	-	-	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	310	200 Max.	600 Max.	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	386	200 Max.	600 Max.	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	37.0	250 Max.	1000 Max.	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	41.2	200 Max.	400 Max.	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	42.3	45 Max.	No relaxation	APHA 24th Ed. 2023,4500-NO_3, B

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

GW-1531260418

TEST REPORT

Report No.:	ME-1531260418	Date: 25.04.2026
ULR No.:	TC748726000008705F	

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
13.	Calcium (as Ca)	mg/L	89.0	75 Max.	200 Max.	APHA 24th Ed. 2023, 3500-Ca-B
14.	Magnesium (as Mg)	mg/L	39.9	30 Max.	100 Max.	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.22	1 Max.	1.5 Max.	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.3	-	-	APHA 24th Ed. 2023, 4500-O, B & C
17.	Oil and Grease	mg/L	BQL (LOQ:1)	-	-	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	0.05 Max.	No relaxation	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	0.001 Max.	0.002 Max.	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water					
20.	Boron (as B)	mg/L	BQL (LOQ:0.02)	0.5 Max.	2.4 Max.	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.076	1.0 Max.	No relaxation	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	BQL (LOQ:0.01)	0.1 Max.	0.3 Max.	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	0.03 Max.	0.2 Max.	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	0.003Max	No relaxation	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	0.05 Max.	No relaxation	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	0.05 Max.	1.5 Max.	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	BQL (LOQ:0.02)	5 Max.	15 Max.	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	0.001Max	No relaxation	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. # Acceptable Limit as per IS 10500:2012
4. $ Permissible Limit in the Absence of Alternate Source as per IS 10500:2012
5. The result listed refers only to the tested sample(s) and applicable parameter(s).
6. This report is not to be reproduced except in full, without the written approval of the laboratory.
7. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

GW-1532260418

TEST REPORT

Report No.:	ME-1532260418	Date: 25.04.2026
ULR No.:	TC748726000008706F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ground water	Sampling Done by	Laboratory
Sampling Location	Village Wagholi	Sample Quantity / Packing	3L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	25.04.2026

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Ground Water)					
1.	Colour	Hazen	BQL (LOQ:1)	5 Max.	15 Max.	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.3	1 Max.	5 Max.	APHA 24th Ed. 2023, 2130-B
4.	pH (at 25°C)	-	7.1	6.5 to 8.5	No relaxation	APHA 24th Ed. 2023, 4500-H+-B
5.	Residual Chlorine (Free)	mg/L	BQL (LOQ:0.05)	0.2 Min.	1.0 Min.	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids (at 180°C)	mg/L	785	500 Max.	2000 Max.	IS 3025 (Part 16):2023
7.	Total Suspended Solids (at 105°C)	mg/L	BQL (LOQ:5)	-	-	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	468	200 Max.	600 Max.	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	600	200 Max.	600 Max.	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	94.0	250 Max.	1000 Max.	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	51.6	200 Max.	400 Max.	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	14.6	45 Max.	No relaxation	APHA 24th Ed. 2023,4500-NO_3, B
13.	Calcium (as Ca)	mg/L	133	75 Max.	200 Max.	APHA 24th Ed. 2023, 3500-Ca-B

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

GW-1532260418

TEST REPORT

Report No.:	ME-1532260418	Date: 25.04.2026
ULR No.:	TC748726000008706F	

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
14.	Magnesium (as Mg)	mg/L	65.1	30 Max.	100 Max.	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.20	1 Max.	1.5 Max.	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.1	-	-	APHA 24th Ed. 2023, 4500-O, B & C
17.	Oil and Grease	mg/L	BQL (LOQ:1)	-	-	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	0.05 Max.	No relaxation	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	0.001 Max.	0.002 Max.	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water					
20.	Boron (as B)	mg/L	BQL (LOQ:0.02)	0.5 Max.	2.4 Max.	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.274	1.0 Max.	No relaxation	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	0.011	0.1 Max.	0.3 Max.	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	0.03 Max.	0.2 Max.	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	0.003Max	No relaxation	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	0.05 Max.	No relaxation	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	0.05 Max.	1.5 Max.	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	BQL (LOQ:0.02)	5 Max.	15 Max.	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	0.001Max	No relaxation	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. # Acceptable Limit as per IS 10500:2012
4. $ Permissible Limit in the Absence of Alternate Source as per IS 10500:2012
5. The result listed refers only to the tested sample(s) and applicable parameter(s).
6. This report is not to be reproduced except in full, without the written approval of the laboratory.
7. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

MEEPL

MAHABAL ENVIRO ENGINEERS P. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

DE-1535260418

TEST REPORT

Report No.:	ME-1535260418	Date: 25.04.2026
ULR No.:	TC748726000008709F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Domestic Effluent	Sampling Done by	Laboratory
Sampling Location	Colony STP Outlet	Sample Quantity / Packing	2 L X 1 No. PVC Can 250mL X 1 No. PVC Can
Date of Sampling	18.04.2026	Date of Receipt of Sample	18.04.2026
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	18.04.2026	Date of Completion of Analysis	25.04.2026

Sr. No.	Parameter	Unit	Result	# Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Pollution & Environment (Waste Water)				
1.	pH (at 25°C)	-	6.7	6.5 to 8.5	APHA 24th Ed. 2023, 4500-H^+-B
2.	Biochemical Oxygen Demand (3 days 27°C)	mg/L	16	30 Max.	IS 3025 (Part 44):2023
3.	Chemical Oxygen Demand	mg/L	56	250 Max.	APHA 24th Ed. 2023, 5220-B

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. #: Limit as per MPCB Consent.
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Harish Mendhi
Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P.LTD. Laboratory Division

TC-7487