Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1239251018

Report No.:	ME-1239251018	Date: 28.10.2025
ULR No.:	TC748725000019449F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No.1	Sample Quantity / Packing	Thimble: 1 X 1 No. SO_2:30 mL X 1 No. PVC Bottle NO_X:25 mL X 1 No. PVC Bottle
Date of Sampling	17.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	20.10.2025	Date of Completion of Analysis	28.10.2025

Stack Details	
Stack Identity	Boiler Unit No. 1
Stack attached to	ESP of Boiler Unit No. 1
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	156
Load at the time of monitoring (MW)	265
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Flue gas Temperature	°C	134	-	IS 11255 (Part 3):2008
2.	Flue gas Velocity	m/s	29.4	-	IS 11255 (Part 3):2008
3.	Flue gas Flow Rate	Nm^3/h	1182257	-	IS 11255 (Part 3):2008
4.	Particulate Matter (PM)	mg/Nm^3	35	50	IS 11255 (Part 1):1985
5.	Sulphur Dioxide (SO_2)	mg/Nm^3	561	600	IS 11255 (Part 2):1985
6.	Oxides of Nitrogen (NO_X)	mg/Nm^3	281	450	IS 11255 (Part 7): 2005

END OF REPORT

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1239251018

Report No.:	ME-1239251018	Date: 28.10.2025
ULR No.:	TC748725000019449F	

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. #: Limit as per MPCB Consent
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and
authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1239251018

Report No.:	ME-1239251018N	Date: 28.10.2025
ULR No.:	-	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No.1	Sample Quantity / Packing	CO: 1L X 1 No. Gas Bladder
Date of Sampling	17.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	20.10.2025	Date of Completion of Analysis	28.10.2025

Stack Details	
Stack Identity	Boiler Unit No. 1
Stack attached to	ESP of Boiler Unit No. 1
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	156
Load at the time of monitoring (MW)	265
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Carbon Monoxide (CO)	mg/Nm^3	19	-	IS 5182 (Part 10): 1999 (NDIR method)

END OF REPORT

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. #: Limit as per MPCB Consent
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P.LTD. Laboratory Division

QF/SALE/04
Issue No 03
Date 05.12.2019.
Amd 03 Date 18.07.2023

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1240251018

Report No.:	ME-1240251018	Date: 28.10.2025
ULR No.:	TC748725000019450F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No. 2	Sample Quantity / Packing	Thimble: 1 X 1 No. SO_2:30 mL X 1 No. PVC Bottle NO_x:25 mL X 1 No. PVC Bottle
Date of Sampling	17.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	20.10.2025	Date of Completion of Analysis	28.10.2025

Stack Details	
Stack Identity	Boiler Unit No. 2
Stack attached to	ESP of Boiler Unit No. 2
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	164
Load at the time of monitoring (MW)	270
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Flue gas Temperature	^0C	143	-	IS 11255 (Part 3):2008
2.	Flue gas Velocity	m/s	30.4	-	IS 11255 (Part 3):2008
3.	Flue gas Flow Rate	Nm^3/h	1176845	-	IS 11255 (Part 3):2008
4.	Particulate Matter (PM)	mg/Nm^3	38	50	IS 11255 (Part 1):1985
5.	Sulphur Dioxide (SO_2)	mg/Nm^3	590	600	IS 11255 (Part 2):1985
6.	Oxides of Nitrogen (NO_x)	mg/Nm^3	272	450	IS 11255 (Part 7): 2005

END OF REPORT

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1240251018

Report No.:	ME-1240251018	Date: 28.10.2025
ULR No.:	TC748725000019450F	

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. #: Limit as per MPCB Consent
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1240251018

Report No.:	ME-1240251018N	Date: 28.10.2025
ULR No.:	-	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No. 2	Sample Quantity / Packing	CO: 1L X 1 No. Gas Bladder
Date of Sampling	17.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	20.10.2025	Date of Completion of Analysis	28.10.2025

Stack Details	
Stack Identity	Boiler Unit No. 2
Stack attached to	ESP of Boiler Unit No. 2
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	164
Load at the time of monitoring (MW)	270
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Carbon Monoxide (CO)	mg/Nm^3	23	-	IS 5182 (Part 10): 1999 (NDIR method)

END OF REPORT

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. #: Limit as per MPCB Consent
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P.LTD. Laboratory Division

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1241251018

Report No.:	ME-1241251018	Date: 28.10.2025
ULR No.:	TC748725000019451F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No. 3	Sample Quantity / Packing	Thimble: 1 X 1 No. SO_2:30 mL X 1 No. PVC Bottle NO_X:25 mL X 1 No. PVC Bottle
Date of Sampling	17.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	20.10.2025	Date of Completion of Analysis	28.10.2025

Stack Details	
Stack Identity	Boiler Unit No. 3
Stack attached to	ESP of Boiler Unit No. 3
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	160
Load at the time of monitoring (MW)	245
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Flue gas Temperature	^0C	131	-	IS 11255 (Part 3):2008
2.	Flue gas Velocity	m/s	29.6	-	IS 11255 (Part 3):2008
3.	Flue gas Flow Rate	Nm^3/h	1206605	-	IS 11255 (Part 3):2008
4.	Particulate Matter (PM)	mg/Nm^3	32	50	IS 11255 (Part 1):1985
5.	Sulphur Dioxide (SO_2)	mg/Nm^3	561	600	IS 11255 (Part 2):1985
6.	Oxides of Nitrogen (NO_X)	mg/Nm^3	267	450	IS 11255 (Part 7): 2005

END OF REPORT

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1241251018

Report No.:	ME-1241251018	Date: 28.10.2025
ULR No.:	TC748725000019451F	

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. #: Limit as per MPCB Consent
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P.LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1241251018

Report No.:	ME-1241251018N	Date: 28.10.2025
ULR No.:	-	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No. 3	Sample Quantity / Packing	CO: 1L X 1 No. Gas Bladder
Date of Sampling	17.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	20.10.2025	Date of Completion of Analysis	28.10.2025

Stack Details	
Stack Identity	Boiler Unit No. 3
Stack attached to	ESP of Boiler Unit No. 3
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	160
Load at the time of monitoring (MW)	245
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Carbon Monoxide (CO)	mg/Nm^3	17	-	IS 5182 (Part 10): 1999 (NDIR method)

END OF REPORT

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. #: Limit as per MPCB Consent
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P.LTD. Laboratory Division

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1242251018

Report No.:	ME-1242251018	Date: 28.10.2025
ULR No.:	TC748725000019452F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No. 4	Sample Quantity / Packing	Thimble: 1 X 1 No. SO_2:30 mL X 1 No. PVC Bottle NO_x:25 mL X 1 No. PVC Bottle
Date of Sampling	17.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	20.10.2025	Date of Completion of Analysis	28.10.2025

Stack Details	
Stack Identity	Boiler Unit No. 4
Stack attached to	ESP of Boiler Unit No. 4
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	134
Load at the time of monitoring (MW)	265
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Flue gas Temperature	^0C	131	-	IS 11255 (Part 3):2008
2.	Flue gas Velocity	m/s	29.9	-	IS 11255 (Part 3):2008
3.	Flue gas Flow Rate	Nm^3/h	1218834	-	IS 11255 (Part 3):2008
4.	Particulate Matter (PM)	mg/Nm^3	34	50	IS 11255 (Part 1):1985
5.	Sulphur Dioxide (SO_2)	mg/Nm^3	470	600	IS 11255 (Part 2):1985
6.	Oxides of Nitrogen (NO_x)	mg/Nm^3	278	450	IS 11255 (Part 7): 2005

END OF REPORT

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1242251018

Report No.:	ME-1242251018	Date: 28.10.2025
ULR No.:	TC748725000019452F	

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. #: Limit as per MPCB Consent
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P.LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1242251018

Report No.:	ME-1242251018N	Date: 28.10.2025
ULR No.:	-	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No. 4	Sample Quantity / Packing	CO: 1L X 1 No. Gas Bladder
Date of Sampling	17.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	20.10.2025	Date of Completion of Analysis	28.10.2025

Stack Details	
Stack Identity	Boiler Unit No. 4
Stack attached to	ESP of Boiler Unit No. 4
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	134
Load at the time of monitoring (MW)	265
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Carbon Monoxide (CO)	mg/Nm^3	20	-	IS 5182 (Part 10): 1999 (NDIR method)

END OF REPORT

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. #: Limit as per MPCB Consent
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1243251018

Report No.:	ME-1243251018	Date: 28.10.2025
ULR No.:	TC748725000019453F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No. 5	Sample Quantity / Packing	Thimble: 1 X 1 No. SO_2:30 mL X 1 No. PVC Bottle NO_X:25 mL X 1 No. PVC Bottle
Date of Sampling	17.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	20.10.2025	Date of Completion of Analysis	28.10.2025

Stack Details	
Stack Identity	Boiler Unit No. 5
Stack attached to	ESP of Boiler Unit No. 5
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	167
Load at the time of monitoring (MW)	260
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Flue gas Temperature	^0C	129	-	IS 11255 (Part 3):2008
2.	Flue gas Velocity	m/s	29.5	-	IS 11255 (Part 3):2008
3.	Flue gas Flow Rate	Nm^3/h	1202529	-	IS 11255 (Part 3):2008
4.	Particulate Matter (PM)	mg/Nm^3	36	50	IS 11255 (Part 1):1985
5.	Sulphur Dioxide (SO_2)	mg/Nm^3	590	600	IS 11255 (Part 2):1985
6.	Oxides of Nitrogen (NO_X)	mg/Nm^3	287	450	IS 11255 (Part 7): 2005

END OF REPORT

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1243251018

Report No.:	ME-1243251018	Date: 28.10.2025
ULR No.:	TC748725000019453F	

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. #: Limit as per MPCB Consent
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1243251018

Report No.:	ME-1243251018N	Date: 28.10.2025
ULR No.:	-	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No. 5	Sample Quantity / Packing	CO: 1L X 1 No. Gas Bladder
Date of Sampling	17.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	20.10.2025	Date of Completion of Analysis	28.10.2025

Stack Details	
Stack Identity	Boiler Unit No. 5
Stack attached to	ESP of Boiler Unit No. 5
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	167
Load at the time of monitoring (MW)	260
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Carbon Monoxide (CO)	mg/Nm^3	23	-	IS 5182 (Part 10): 1999 (NDIR method)

END OF REPORT

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. #: Limit as per MPCB Consent
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1235251018

Report No.:	ME-1235251018	Date: 29.10.2025
ULR No.:	TC748725000019556F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ambient Air	Sampling Done by	Laboratory
Sampling Location	Village Kapustalni	Sample Quantity / Packing	PM_{10}, B(a), Ni, As, Pb: Filter Paper 1 X 3 No. $PM_{2.5}$: Filter Paper 1 X 1 No. SO_2:30 mL X 6 No. PVC Bottle NO_2:30 mL X 6 No. PVC Bottle NH_3:10 mL X 24 No. PVC Bottle O_3:10 mL X 24 No. PVC Bottle Charcoal Tubes: 1 X 6 No. CO:2L X 3No. Gas Bladder
Date of Sampling	17.10.2025 to 18.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	18.10.2025	Date of Completion of Analysis	29.10.2025

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Ambient Air)				
1	Sulphur Dioxide (SO_2)	µg/m³	11.0	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.1-6
2	Nitrogen Dioxide (NO_2)	µg/m³	14.9	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.7-10
3	Particulate Matter (size less than 10µm) or PM_{10}	µg/m³	56	100	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.11-14
4	Particulate Matter (size less than 2.5µm) or $PM_{2.5}$	µg/m³	25	60	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.15-30
5	Ozone (O_3)	µg/m³	20.0	180	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.31-34

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1235251018

Report No.:	ME-1235251018	Date: 29.10.2025
ULR No.:	TC748725000019556F	

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
6	Lead (as Pb)	µg/m³	BQL (LOQ:0.02)	01	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999
7	Carbon Monoxide (CO)	mg/m³	0.77	04	CPCB Guidelines for the Measurement of Ambient Air Pollutants Volume-II, 2012-13, Page No. 16-22, (NDIR method)
8	Ammonia (NH_3)	µg/m³	22.4	400	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.35-39
9	Benzene (C_6H_6)	µg/m³	BQL (LOQ:1)	05	IS 5182 (Part 11): 2006
10	Benzo(a)Pyrene (Particulate phase only)	ng/m³	BQL (LOQ:0.5)	01	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.40-47
11	Arsenic (as As)	ng/m³	BQL (LOQ:0.3)	06	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999
12	Nickel (as Ni)	ng/m³	BQL (LOQ:3)	20	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. TWA: Time Weighted Average
4. Duration of Sampling: 24 h
5. NAAQS: National Ambient Air Quality Standard
6. #- NAAQS specified as: 24 h. TWA in case of Sulphur Dioxide, Nitrogen Dioxide, PM_{10}, $PM_{2.5}$, Lead and Ammonia; 1 h. TWA in case of Carbon Monoxide, Ozone; Annual TWA in case of Benzene, Benzo (a) Pyrene, Arsenic and Nickel.
7. The result listed refers only to the tested sample(s) and applicable parameter(s).
8. This report is not to be reproduced except in full, without the written approval of the laboratory.
9. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1236251018

Report No.:	ME-1236251018	Date: 29.10.2025
ULR No.:	TC748725000019557F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ambient Air	Sampling Done by	Laboratory
Sampling Location	Village Dawargaon	Sample Quantity / Packing	PM_{10}, B(a), Ni, As, Pb: Filter Paper 1 X 3 No. $PM_{2.5}$: Filter Paper 1 X 1 No. SO_2:30 mL X 6 No. PVC Bottle NO_2:30 mL X 6 No. PVC Bottle NH_3:10 mL X 24 No. PVC Bottle O_3:10 mL X 24 No. PVC Bottle Charcoal Tubes: 1 X 6 No. CO:2L X 3No. Gas Bladder
Date of Sampling	17.10.2025 to 18.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	18.10.2025	Date of Completion of Analysis	29.10.2025

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Ambient Air)				
1	Sulphur Dioxide (SO_2)	µg/m³	18.1	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.1-6
2	Nitrogen Dioxide (NO_2)	µg/m³	21.1	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.7-10
3	Particulate Matter (size less than 10µm) or PM_{10}	µg/m³	66	100	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.11-14
4	Particulate Matter (size less than 2.5µm) or $PM_{2.5}$	µg/m³	29	60	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.15-30
5	Ozone (O_3)	µg/m³	19.9	180	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.31-34

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1236251018

Report No.:	ME-1236251018	Date: 29.10.2025
ULR No.:	TC748725000019557F	

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
6	Lead (as Pb)	µg/m³	BQL (LOQ:0.02)	01	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999
7	Carbon Monoxide (CO)	mg/m³	0.86	04	CPCB Guidelines for the Measurement of Ambient Air Pollutants Volume-II, 2012-13, Page No. 16-22, (NDIR method)
8	Ammonia (NH_3)	µg/m³	BQL (LOQ:20)	400	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.35-39
9	Benzene (C_6H_6)	µg/m³	BQL (LOQ:1)	05	IS 5182 (Part 11): 2006
10	Benzo(a)Pyrene (Particulate phase only)	ng/m³	BQL (LOQ:0.5)	01	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.40-47
11	Arsenic (as As)	ng/m³	BQL (LOQ:0.3)	06	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999
12	Nickel (as Ni)	ng/m³	BQL (LOQ:3)	20	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. TWA: Time Weighted Average
4. Duration of Sampling: 24 h
5. NAAQS: National Ambient Air Quality Standard
6. #- NAAQS specified as: 24 h. TWA in case of Sulphur Dioxide, Nitrogen Dioxide, PM_{10}, $PM_{2.5}$, Lead and Ammonia; 1 h. TWA in case of Carbon Monoxide, Ozone; Annual TWA in case of Benzene, Benzo (a) Pyrene, Arsenic and Nickel.
7. The result listed refers only to the tested sample(s) and applicable parameter(s).
8. This report is not to be reproduced except in full, without the written approval of the laboratory.
9. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1237251018

Report No.:	ME-1237251018	Date: 29.10.2025
ULR No.:	TC748725000019558F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ambient Air	Sampling Done by	Laboratory
Sampling Location	Village Wagholi Gate	Sample Quantity / Packing	PM_{10}, B(a), Ni, As, Pb: Filter Paper 1 X 3 No. $PM_{2.5}$: Filter Paper 1 X 1 No. SO_2:30 mL X 6 No. PVC Bottle NO_2:30 mL X 6 No. PVC Bottle NH_3:10 mL X 24 No. PVC Bottle O_3:10 mL X 24 No. PVC Bottle Charcoal Tubes: 1 X 6 No. CO:2L X 3No. Gas Bladder
Date of Sampling	17.10.2025 to 18.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	18.10.2025	Date of Completion of Analysis	29.10.2025

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Ambient Air)				
1	Sulphur Dioxide (SO_2)	µg/m³	16.6	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.1-6
2	Nitrogen Dioxide (NO_2)	µg/m³	21.1	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.7-10
3	Particulate Matter (size less than 10µm) or PM_{10}	µg/m³	70	100	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.11-14
4	Particulate Matter (size less than 2.5µm) or $PM_{2.5}$	µg/m³	34	60	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.15-30
5	Ozone (O_3)	µg/m³	BQL (LOQ:19.6)	180	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.31-34

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1237251018

Report No.:	ME-1237251018	Date: 29.10.2025
ULR No.:	TC748725000019558F	

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
6	Lead (as Pb)	µg/m³	BQL (LOQ:0.02)	01	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999
7	Carbon Monoxide (CO)	mg/m³	0.68	04	CPCB Guidelines for the Measurement of Ambient Air Pollutants Volume-II, 2012-13, Page No. 16-22, (NDIR method)
8	Ammonia (NH_3)	µg/m³	21.4	400	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.35-39
9	Benzene (C_6H_6)	µg/m³	BQL (LOQ:1)	05	IS 5182 (Part 11): 2006
10	Benzo(a)Pyrene (Particulate phase only)	ng/m³	BQL (LOQ:0.5)	01	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.40-47
11	Arsenic (as As)	ng/m³	BQL (LOQ:0.3)	06	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999
12	Nickel (as Ni)	ng/m³	BQL (LOQ:3)	20	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. TWA: Time Weighted Average
4. Duration of Sampling: 24 h
5. NAAQS: National Ambient Air Quality Standard
6. #- NAAQS specified as: 24 h. TWA in case of Sulphur Dioxide, Nitrogen Dioxide, PM_{10}, $PM_{2.5}$, Lead and Ammonia; 1 h. TWA in case of Carbon Monoxide, Ozone; Annual TWA in case of Benzene, Benzo (a) Pyrene, Arsenic and Nickel.
7. The result listed refers only to the tested sample(s) and applicable parameter(s).
8. This report is not to be reproduced except in full, without the written approval of the laboratory.
9. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: 0712-2612162/2612212 email: nagpur@mahabal.com

TEST REPORT

AA-1238251018

Report No.:	ME-1238251018	Date: 29.10.2025
ULR No.:	TC748725000019559F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ambient Air	Sampling Done by	Laboratory
Sampling Location	Terrace of Bachelor Guest House	Sample Quantity / Packing	PM_{10}, B(a), Ni, As, Pb: Filter Paper 1 X 3 No. $PM_{2.5}$: Filter Paper 1 X 1 No. SO_2:30 mL X 6 No. PVC Bottle NO_2:30 mL X 6 No. PVC Bottle NH_3:10 mL X 24 No. PVC Bottle O_3:10 mL X 24 No. PVC Bottle Charcoal Tubes: 1 X 6 No. CO:2L X 3No. Gas Bladder
Date of Sampling	17.10.2025 to 18.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	18.10.2025	Date of Completion of Analysis	29.10.2025

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Ambient Air)				
1	Sulphur Dioxide (SO_2)	µg/m³	14.3	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.1-6
2	Nitrogen Dioxide (NO_2)	µg/m³	18.8	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.7-10
3	Particulate Matter (size less than 10µm) or PM_{10}	µg/m³	72	100	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.11-14
4	Particulate Matter (size less than 2.5µm) or $PM_{2.5}$	µg/m³	33	60	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.15-30
5	Ozone (O_3)	µg/m³	BQL (LOQ:19.6)	180	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.31-34

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1238251018

Report No.:	ME-1238251018	Date: 29.10.2025
ULR No.:	TC748725000019559F	

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
6	Lead (as Pb)	µg/m³	BQL (LOQ:0.02)	01	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999
7	Carbon Monoxide (CO)	mg/m³	1.00	04	CPCB Guidelines for the Measurement of Ambient Air Pollutants Volume-II, 2012-13, Page No. 16-22, (NDIR method)
8	Ammonia (NH_3)	µg/m³	23.2	400	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.35-39
9	Benzene (C_6H_6)	µg/m³	BQL (LOQ:1)	05	IS 5182 (Part 11): 2006
10	Benzo(a)Pyrene (Particulate phase only)	ng/m³	BQL (LOQ:0.5)	01	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.40-47
11	Arsenic (as As)	ng/m³	BQL (LOQ:0.3)	06	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999
12	Nickel (as Ni)	ng/m³	BQL (LOQ:3)	20	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. TWA: Time Weighted Average
4. Duration of Sampling: 24 h
5. NAAQS: National Ambient Air Quality Standard
6. #- NAAQS specified as: 24 h. TWA in case of Sulphur Dioxide, Nitrogen Dioxide, PM_{10}, $PM_{2.5}$, Lead and Ammonia; 1 h. TWA in case of Carbon Monoxide, Ozone; Annual TWA in case of Benzene, Benzo (a) Pyrene, Arsenic and Nickel.
7. The result listed refers only to the tested sample(s) and applicable parameter(s).
8. This report is not to be reproduced except in full, without the written approval of the laboratory.
9. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P.LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

WNA-1244251018

Report No.:	ME-1244251018	Date: 28.10.2025
ULR No.:	TC748725000019454F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**	SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Workroom Noise	
Date of Sampling	17.10.2025	
Sampling Procedure	CPCB Protocol for Ambient level Noise Monitoring 2015	

Sr. No.	Location	Time in h	Sound Level L_{eq} dB (A)	
			L_{min}	L_{max}
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Workroom Noise)			
1.	Turbine Area No. 3 & 4	10:00 to 10:05	67.1	72.8
2.	Near CHP Crusher House	10:20 to 10:25	61.5	66.9
3.	Near Compressor Room	11:00 to 11:05	66.7	68.8
4.	Near Main Gate	09:35 to 09:40	60.9	63.7
5.	Near Colony	09:50 to 09:55	58.8	64.3

Limit as per The Factories Act, 1948, The Maharashtra Factory Rules, 1963, Schedule XXIV	
Total time of exposure per day, in hours.	**Max. Sound pressure level in dB (A)**
8	90
6	92
4	95
3	97
2	100
1 ½	102
1	105
¾	107
½	110
¼	115

END OF REPORT

Note:
1. The result listed refers only to the tested sample(s) and applicable parameter(s).
2. This report is not to be reproduced except in full, without the written approval of the laboratory.
3. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P. LTD. Laboratory Division

TC-7457

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

DE-1257251018

Report No.:	ME-1257251018	Date: 29.10.2025
ULR No.:	TC748725000019572F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Domestic Effluent	Sampling Done by	Laboratory
Sampling Location	Colony STP Outlet	Sample Quantity / Packing	2 L X 1 No. PVC Can 250mL X 1 No. PVC Can
Date of Sampling	18.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	IS 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	18.10.2025	Date of Completion of Analysis	29.10.2025

Sr. No.	Parameter	Unit	Result	# Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Pollution & Environment (Waste Water)				
1.	pH (at 25°C)	-	8.5	6.5 to 8.5	APHA 24th Ed. 2023, 4500-H^+-B
2.	Biochemical Oxygen Demand (3 days 27°C)	mg/L	7.5	30 Max.	IS 3025 (Part 44):2023
3.	Chemical Oxygen Demand	mg/L	28	250 Max.	APHA 24th Ed. 2023, 5220-B

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. #: Limit as per MPCB Consent.
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGG. PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SW-1245251018

Report No.:	ME-1245251018	Date: 29.10.2025
ULR No.:	TC748725000019560F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Surface water	Sampling Done by	Laboratory
Sampling Location	Malegaon Pond	Sample Quantity / Packing	2L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	18.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	18.10.2025	Date of Completion of Analysis	29.10.2025

Sr. No.	Parameter	Unit	Result	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Surface Water)			
1.	Colour	Hazen	BQL (LOQ:1)	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.7	APHA 24th Ed. 2023, 2130-B
4.	pH (at 25°C)	-	7.9	APHA 24th Ed. 2023, 4500-H+-B
5.	Free Chlorine (Residual)	mg/L	BQL (LOQ:0.05)	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids (at 180°C)	mg/L	611	IS 3025 (Part 16):2023
7.	Total Suspended Solids (at 105°C)	mg/L	BQL (LOQ:5)	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	170	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	464	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	76.0	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	235	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	1.60	APHA 24th Ed. 2023,4500-NO_3, E
13.	Calcium (as Ca)	mg/L	119	APHA 24th Ed. 2023, 3500-Ca-B
14.	Magnesium (as Mg)	mg/L	40.8	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.68	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.3	APHA 24th Ed. 2023, 4500-O, B & C

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SW-1245251018

Report No.:	ME-1245251018	Date: 29.10.2025
ULR No.:	TC748725000019560F	

Sr. No.	Parameter	Unit	Result	Method Reference
17.	Oil and Grease	mg/L	BQL (LOQ:1)	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water			
20.	Boron (as B)	mg/L	0.144	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.199	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	0.028	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	BQL (LOQ:0.02)	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. The result listed refers only to the tested sample(s) and applicable parameter(s).
4. This report is not to be reproduced except in full, without the written approval of the laboratory.
5. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SW-1246251018

Report No.:	ME-1246251018	Date: 29.10.2025
ULR No.:	TC748725000019561F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Surface water	Sampling Done by	Laboratory
Sampling Location	Wagholi Pond	Sample Quantity / Packing	2L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	18.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	18.10.2025	Date of Completion of Analysis	29.10.2025

Sr. No.	Parameter	Unit	Result	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Surface Water)			
1.	Colour	Hazen	BQL (LOQ:1)	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	1.0	APHA 24th Ed. 2023, 2130-B
4.	pH (at 25°C)	-	7.9	APHA 24th Ed. 2023, 4500-H+-B
5.	Free Chlorine (Residual)	mg/L	BQL (LOQ:0.05)	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids (at 180°C)	mg/L	617	IS 3025 (Part 16):2023
7.	Total Suspended Solids (at 105°C)	mg/L	BQL (LOQ:5)	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	164	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	456	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	81.0	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	223	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	1.54	APHA 24th Ed. 2023,4500-NO_3, E
13.	Calcium (as Ca)	mg/L	119	APHA 24th Ed. 2023, 3500-Ca-B
14.	Magnesium (as Mg)	mg/L	38.9	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.83	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.4	APHA 24th Ed. 2023, 4500-O, B & C

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SW-1246251018

Report No.:	ME-1246251018	Date: 29.10.2025
ULR No.:	TC748725000019561F	

Sr. No.	Parameter	Unit	Result	Method Reference
17.	Oil and Grease	mg/L	BQL (LOQ:1)	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water			
20.	Boron (as B)	mg/L	0.144	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.118	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	0.033	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	BQL (LOQ:0.02)	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. The result listed refers only to the tested sample(s) and applicable parameter(s).
4. This report is not to be reproduced except in full, without the written approval of the laboratory.
5. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1247251018

Report No.:	ME-1247251018	Date: 29.10.2025
ULR No.:	TC748725000019562F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ground water	Sampling Done by	Laboratory
Sampling Location	Village Pimpalvihirgaon	Sample Quantity / Packing	2L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	18.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	18.10.2025	Date of Completion of Analysis	29.10.2025

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Ground Water)					
1.	Colour	Hazen	BQL (LOQ:1)	5 Max.	15 Max.	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.8	1 Max.	5 Max.	APHA 24th Ed. 2023, 2130-B
4.	pH (at 25°C)	-	7.4	6.5 to 8.5	No relaxation	APHA 24th Ed. 2023, 4500-H+-B
5.	Free Chlorine (Residual)	mg/L	BQL (LOQ:0.05)	0.2 Min.	1.0 Max.	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids (at 180°C)	mg/L	462	500 Max.	2000 Max.	IS 3025 (Part 16):2023
7.	Total Suspended Solids (at 105°C)	mg/L	BQL (LOQ:5)	-	-	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	308	200 Max.	600 Max.	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	364	200 Max.	600 Max.	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	30.5	250 Max.	1000 Max.	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	27.9	200 Max.	400 Max.	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	42.6	45 Max.	No relaxation	APHA 24th Ed. 2023,4500-NO_3, B

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1247251018

Report No.:	ME-1247251018	Date: 29.10.2025
ULR No.:	TC748725000019562F	

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
13.	Calcium (as Ca)	mg/L	112	75 Max.	200 Max.	APHA 24th Ed. 2023, 3500-Ca-B
14.	Magnesium (as Mg)	mg/L	20.4	30 Max.	100 Max.	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.73	1 Max.	1.5 Max.	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.3	-	-	APHA 24th Ed. 2023, 4500-O, B & C
17.	Oil and Grease	mg/L	BQL (LOQ:1)	-	-	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	0.05 Max.	No relaxation	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	0.001 Max.	0.002 Max.	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water					
20.	Boron (as B)	mg/L	BQL(LOQ:0.02)	0.5 Max.	2.4 Max.	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.174	1.0 Max.	No relaxation	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	BQL (LOQ:0.01)	0.1 Max.	0.3 Max.	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	0.03 Max.	0.2 Max.	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	0.003Max	No relaxation	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	0.05 Max.	No relaxation	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	0.05 Max.	1.5 Max.	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	BQL (LOQ:0.02)	5 Max.	15 Max.	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	0.001Max	No relaxation	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. # Acceptable Limit as per IS 10500:2012
4. $ Permissible Limit in the Absence of Alternate Source as per IS 10500:2012
5. The result listed refers only to the tested sample(s) and applicable parameter(s).
6. This report is not to be reproduced except in full, without the written approval of the laboratory.
7. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MEEPL

MAHABAL ENVIRO ENGG. PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1248251018

Report No.:	ME-1248251018	Date: 29.10.2025
ULR No.:	TC748725000019563F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ground water	Sampling Done by	Laboratory
Sampling Location	Village Digargaon	Sample Quantity / Packing	2L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	18.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	18.10.2025	Date of Completion of Analysis	29.10.2025

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Ground Water)					
1.	Colour	Hazen	BQL (LOQ:1)	5 Max.	15 Max.	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.8	1 Max.	5 Max.	APHA 24th Ed. 2023, 2130-B
4.	pH (at 25°C)	-	7.1	6.5 to 8.5	No relaxation	APHA 24th Ed. 2023, 4500-H+-B
5.	Free Chlorine (Residual)	mg/L	BQL (LOQ:0.05)	0.2 Min.	1.0 Max.	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids (at 180°C)	mg/L	467	500 Max.	2000 Max.	IS 3025 (Part 16):2023
7.	Total Suspended Solids (at 105°C)	mg/L	BQL (LOQ:5)	-	-	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	290	200 Max.	600 Max.	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	356	200 Max.	600 Max.	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	28.5	250 Max.	1000 Max.	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	33.7	200 Max.	400 Max.	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	42.5	45 Max.	No relaxation	APHA 24th Ed. 2023,4500-NO_3, B
13.	Calcium (as Ca)	mg/L	112	75 Max.	200 Max.	APHA 24th Ed. 2023, 3500-Ca-B

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1248251018

Report No.:	ME-1248251018	Date: 29.10.2025
ULR No.:	TC748725000019563F	

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
14.	Magnesium (as Mg)	mg/L	18.5	30 Max.	100 Max.	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.66	1 Max.	1.5 Max.	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.7	-	-	APHA 24th Ed. 2023, 4500-O, B & C
17.	Oil and Grease	mg/L	BQL (LOQ:1)	-	-	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	0.05 Max.	No relaxation	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	0.001 Max.	0.002 Max.	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water					
20.	Boron (as B)	mg/L	BQL(LOQ:0.02)	0.5 Max.	2.4 Max.	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.186	1.0 Max.	No relaxation	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	BQL (LOQ:0.01)	0.1 Max.	0.3 Max.	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	0.03 Max.	0.2 Max.	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	0.003Max	No relaxation	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	0.05 Max.	No relaxation	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	0.05 Max.	1.5 Max.	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	0.026	5 Max.	15 Max.	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	0.001Max	No relaxation	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. # Acceptable Limit as per IS 10500:2012
4. $ Permissible Limit in the Absence of Alternate Source as per IS 10500:2012
5. The result listed refers only to the tested sample(s) and applicable parameter(s).
6. This report is not to be reproduced except in full, without the written approval of the laboratory.
7. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGG. Laboratory Division

TC-7467

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1249251018

Report No.:	ME-1249251018	Date: 29.10.2025
ULR No.:	TC748725000019564F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ground water	Sampling Done by	Laboratory
Sampling Location	Village Talkhanda	Sample Quantity / Packing	2L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	18.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	18.10.2025	Date of Completion of Analysis	29.10.2025

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Ground Water)					
1.	Colour	Hazen	BQL (LOQ:1)	5 Max.	15 Max.	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.5	1 Max.	5 Max.	APHA 24th Ed. 2023, 2130-B
4.	pH (at 25°C)	-	7.3	6.5 to 8.5	No relaxation	APHA 24th Ed. 2023, 4500-H+-B
5.	Free Chlorine (Residual)	mg/L	BQL (LOQ:0.05)	0.2 Min.	1.0 Max.	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids (at 180°C)	mg/L	469	500 Max.	2000 Max.	IS 3025 (Part 16):2023
7.	Total Suspended Solids (at 105°C)	mg/L	BQL (LOQ:5)	-	-	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	294	200 Max.	600 Max.	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	390	200 Max.	600 Max.	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	31.0	250 Max.	1000 Max.	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	32.7	200 Max.	400 Max.	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	42.5	45 Max.	No relaxation	APHA 24th Ed. 2023,4500-NO_3, B
13.	Calcium (as Ca)	mg/L	115	75 Max.	200 Max.	APHA 24th Ed. 2023, 3500-Ca-B

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1249251018

Report No.:	ME-1249251018	Date: 29.10.2025
ULR No.:	TC748725000019564F	

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
14.	Magnesium (as Mg)	mg/L	24.8	30 Max.	100 Max.	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.62	1 Max.	1.5 Max.	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.3	-	-	APHA 24th Ed. 2023, 4500-O, B & C
17.	Oil and Grease	mg/L	BQL (LOQ:1)	-	-	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	0.05 Max.	No relaxation	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	0.001 Max.	0.002 Max.	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water					
20.	Boron (as B)	mg/L	BQL(LOQ:0.02)	0.5 Max.	2.4 Max.	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.146	1.0 Max.	No relaxation	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	BQL (LOQ:0.01)	0.1 Max.	0.3 Max.	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	0.03 Max.	0.2 Max.	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	0.003Max	No relaxation	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	0.05 Max.	No relaxation	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	0.05 Max.	1.5 Max.	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	BQL (LOQ:0.02)	5 Max.	15 Max.	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	0.001Max	No relaxation	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. # Acceptable Limit as per IS 10500:2012
4. $ Permissible Limit in the Absence of Alternate Source as per IS 10500:2012
5. The result listed refers only to the tested sample(s) and applicable parameter(s).
6. This report is not to be reproduced except in full, without the written approval of the laboratory.
7. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MEEPL

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1250251018

Report No.:	ME-1250251018	Date: 29.10.2025
ULR No.:	TC748725000019565F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ground water	Sampling Done by	Laboratory
Sampling Location	Backside of Ash dyke Area Mr.N.Lomte farm	Sample Quantity / Packing	2L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	18.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	18.10.2025	Date of Completion of Analysis	29.10.2025

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Ground Water)					
1.	Colour	Hazen	BQL (LOQ:1)	5 Max.	15 Max.	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.4	1 Max.	5 Max.	APHA 24th Ed. 2023, 2130-B
4.	pH (at 25°C)	-	7.1	6.5 to 8.5	No relaxation	APHA 24th Ed. 2023, 4500-H+-B
5.	Free Chlorine (Residual)	mg/L	BQL (LOQ:0.05)	0.2 Min.	1.0 Max.	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids (at 180°C)	mg/L	466	500 Max.	2000 Max.	IS 3025 (Part 16):2023
7.	Total Suspended Solids (at 105°C)	mg/L	BQL (LOQ:5)	-	-	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	290	200 Max.	600 Max.	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	388	200 Max.	600 Max.	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	34.0	250 Max.	1000 Max.	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	33.5	200 Max.	400 Max.	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	42.3	45 Max.	No relaxation	APHA 24th Ed. 2023,4500-NO_3, B

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1250251018

Report No.:	ME-1250251018	Date: 29.10.2025
ULR No.:	TC748725000019565F	

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
13.	Calcium (as Ca)	mg/L	115	75 Max.	200 Max.	APHA 24th Ed. 2023, 3500-Ca-B
14.	Magnesium (as Mg)	mg/L	24.3	30 Max.	100 Max.	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.52	1 Max.	1.5 Max.	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.6	-	-	APHA 24th Ed. 2023, 4500-O, B & C
17.	Oil and Grease	mg/L	BQL (LOQ:1)	-	-	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	0.05 Max.	No relaxation	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	0.001 Max.	0.002 Max.	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water					
20.	Boron (as B)	mg/L	BQL(LOQ:0.02)	0.5 Max.	2.4 Max.	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.161	1.0 Max.	No relaxation	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	BQL (LOQ:0.01)	0.1 Max.	0.3 Max.	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	0.03 Max.	0.2 Max.	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	0.003Max	No relaxation	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	0.05 Max.	No relaxation	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	0.05 Max.	1.5 Max.	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	0.020	5 Max.	15 Max.	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	0.001Max	No relaxation	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. # Acceptable Limit as per IS 10500:2012
4. $ Permissible Limit in the Absence of Alternate Source as per IS 10500:2012
5. The result listed refers only to the tested sample(s) and applicable parameter(s).
6. This report is not to be reproduced except in full, without the written approval of the laboratory.
7. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGG. PVT. LTD. Laboratory Division

TC-7497

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1251251018

Report No.:	ME-1251251018	Date: 29.10.2025
ULR No.:	TC748725000019566F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ground water	Sampling Done by	Laboratory
Sampling Location	Village Kapustalni	Sample Quantity / Packing	2L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	18.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	18.10.2025	Date of Completion of Analysis	29.10.2025

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Ground Water)					
1.	Colour	Hazen	BQL (LOQ:1)	5 Max.	15 Max.	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.6	1 Max.	5 Max.	APHA 24th Ed. 2023, 2130-B
4.	pH (at 25°C)	-	7.2	6.5 to 8.5	No relaxation	APHA 24th Ed. 2023, 4500-H+-B
5.	Free Chlorine (Residual)	mg/L	BQL (LOQ:0.05)	0.2 Min.	1.0 Max.	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids (at 180°C)	mg/L	463	500 Max.	2000 Max.	IS 3025 (Part 16):2023
7.	Total Suspended Solids (at 105°C)	mg/L	BQL (LOQ:5)	-	-	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	298	200 Max.	600 Max.	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	346	200 Max.	600 Max.	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	29.0	250 Max.	1000 Max.	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	33.7	200 Max.	400 Max.	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	42.4	45 Max.	No relaxation	APHA 24th Ed. 2023,4500-NO_3, B
13.	Calcium (as Ca)	mg/L	104	75 Max.	200 Max.	APHA 24th Ed. 2023, 3500-Ca-B

Reviewed and authorised by

- **Sagar Yeul**
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1251251018

Report No.:	ME-1251251018	Date: 29.10.2025
ULR No.:	TC748725000019566F	

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
14.	Magnesium (as Mg)	mg/L	20.9	30 Max.	100 Max.	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.63	1 Max.	1.5 Max.	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.6	-	-	APHA 24th Ed. 2023, 4500-O, B & C
17.	Oil and Grease	mg/L	BQL (LOQ:1)	-	-	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	0.05 Max.	No relaxation	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	0.001 Max.	0.002 Max.	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water					
20.	Boron (as B)	mg/L	BQL(LOQ:0.02)	0.5 Max.	2.4 Max.	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.126	1.0 Max.	No relaxation	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	BQL (LOQ:0.01)	0.1 Max.	0.3 Max.	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	0.03 Max.	0.2 Max.	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	0.003Max	No relaxation	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	0.05 Max.	No relaxation	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	0.05 Max.	1.5 Max.	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	BQL (LOQ:0.02)	5 Max.	15 Max.	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	0.001Max	No relaxation	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. # Acceptable Limit as per IS 10500:2012
4. $ Permissible Limit in the Absence of Alternate Source as per IS 10500:2012
5. The result listed refers only to the tested sample(s) and applicable parameter(s).
6. This report is not to be reproduced except in full, without the written approval of the laboratory.
7. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGG. PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1252251018

Report No.:	ME-1252251018	Date: 29.10.2025
ULR No.:	TC748725000019567F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ground water	Sampling Done by	Laboratory
Sampling Location	Village Wagholi	Sample Quantity / Packing	2L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	18.10.2025	Date of Receipt of Sample	18.10.2025
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	18.10.2025	Date of Completion of Analysis	29.10.2025

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Ground Water)					
1.	Colour	Hazen	BQL (LOQ:1)	5 Max.	15 Max.	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.4	1 Max.	5 Max.	APHA 24th Ed. 2023, 2130-B
4.	pH (at 25°C)	-	7.0	6.5 to 8.5	No relaxation	APHA 24th Ed. 2023, 4500-H+-B
5.	Free Chlorine (Residual)	mg/L	BQL (LOQ:0.05)	0.2 Min.	1.0 Max.	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids (at 180°C)	mg/L	655	500 Max.	2000 Max.	IS 3025 (Part 16):2023
7.	Total Suspended Solids (at 105°C)	mg/L	BQL (LOQ:5)	-	-	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	200	200 Max.	600 Max.	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	504	200 Max.	600 Max.	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	77.0	250 Max.	1000 Max.	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	224	200 Max.	400 Max.	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	3.72	45 Max.	No relaxation	APHA 24th Ed. 2023,4500-NO_3, B
13.	Calcium (as Ca)	mg/L	149	75 Max.	200 Max.	APHA 24th Ed. 2023, 3500-Ca-B

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1252251018

Report No.:	ME-1252251018	Date: 29.10.2025
ULR No.:	TC748725000019567F	

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
14.	Magnesium (as Mg)	mg/L	32.1	30 Max.	100 Max.	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.53	1 Max.	1.5 Max.	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.5	-	-	APHA 24th Ed. 2023, 4500-O, B & C
17.	Oil and Grease	mg/L	BQL (LOQ:1)	-	-	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	0.05 Max.	No relaxation	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	0.001 Max.	0.002 Max.	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water					
20.	Boron (as B)	mg/L	BQL(LOQ:0.02)	0.5 Max.	2.4 Max.	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.465	1.0 Max.	No relaxation	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	0.013	0.1 Max.	0.3 Max.	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	0.03 Max.	0.2 Max.	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	0.003Max	No relaxation	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	0.05 Max.	No relaxation	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	0.05 Max.	1.5 Max.	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	BQL (LOQ:0.02)	5 Max.	15 Max.	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	0.001Max	No relaxation	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. # Acceptable Limit as per IS 10500:2012
4. $ Permissible Limit in the Absence of Alternate Source as per IS 10500:2012
5. The result listed refers only to the tested sample(s) and applicable parameter(s).
6. This report is not to be reproduced except in full, without the written approval of the laboratory.
7. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGG. Laboratory Division

TC-7487