Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1601250923

Report No.:	ME-1601250923	Date: 29.09.2025
ULR No.:	TC748725000017725F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No.1	Sample Quantity / Packing	Thimble: 1 X 1 No. SO_2:30 mL X 1 No. PVC Bottle NO_X:25 mL X 1 No. PVC Bottle CO: 1L X 1 No. Gas Bladder
Date of Sampling	22.09.2025	Date of Receipt of Sample	23.09.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	23.09.2025	Date of Completion of Analysis	29.09.2025

Stack Details	
Stack Identity	Boiler Unit No. 1
Stack attached to	ESP of Boiler Unit No. 1
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	107
Load at the time of monitoring (MW)	159
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Flue gas Temperature	^0C	123	-	IS 11255 (Part 3):2008
2.	Flue gas Velocity	m/s	26.9	-	IS 11255 (Part 3):2008
3.	Flue gas Flow Rate	Nm^3/h	1123184	-	IS 11255 (Part 3):2008
4.	Particulate Matter (PM)	mg/Nm^3	35	50	IS 11255 (Part 1):1985
5.	Sulphur Dioxide (SO_2)	mg/Nm^3	516	600	IS 11255 (Part 2):1985
6.	Oxides of Nitrogen (NO_X)	mg/Nm^3	263	450	IS 11255 (Part 7): 2005
7.	Carbon Monoxide (CO)	mg/Nm^3	15	-	IS 5182 (Part 10): 1999 (NDIR method)

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1601250923

Report No.:	ME-1601250923	Date: 29.09.2025
ULR No.:	TC748725000017725F	

END OF REPORT

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. #: Limit as per MPCB Consent
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1602250923

Report No.:	ME-1602250923	Date: 29.09.2025
ULR No.:	TC748725000017726F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No. 2	Sample Quantity / Packing	Thimble: 1 X 1 No. SO_2:30 mL X 1 No. PVC Bottle NO_X:25 mL X 1 No. PVC Bottle CO: 1L X 1 No. Gas Bladder
Date of Sampling	22.09.2025	Date of Receipt of Sample	23.09.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	23.09.2025	Date of Completion of Analysis	29.09.2025

Stack Details	
Stack Identity	Boiler Unit No. 2
Stack attached to	ESP of Boiler Unit No. 2
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	114
Load at the time of monitoring (MW)	157
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Flue gas Temperature	^0C	136	-	IS 11255 (Part 3):2008
2.	Flue gas Velocity	m/s	27.3	-	IS 11255 (Part 3):2008
3.	Flue gas Flow Rate	Nm^3/h	1109489	-	IS 11255 (Part 3):2008
4.	Particulate Matter (PM)	mg/Nm^3	38	50	IS 11255 (Part 1):1985
5.	Sulphur Dioxide (SO_2)	mg/Nm^3	556	600	IS 11255 (Part 2):1985
6.	Oxides of Nitrogen (NO_X)	mg/Nm^3	278	450	IS 11255 (Part 7): 2005
7.	Carbon Monoxide (CO)	mg/Nm^3	22	-	IS 5182 (Part 10): 1999 (NDIR method)

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1602250923

Report No.:	ME-1602250923	Date: 29.09.2025
ULR No.:	TC748725000017726F	

END OF REPORT

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. #: Limit as per MPCB Consent
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1603250923

Report No.:	ME-1603250923	Date: 29.09.2025
ULR No.:	TC748725000017727F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No. 3	Sample Quantity / Packing	Thimble: 1 X 1 No. SO_2:30 mL X 1 No. PVC Bottle NO_X:25 mL X 1 No. PVC Bottle CO: 1L X 1 No. Gas Bladder
Date of Sampling	22.09.2025	Date of Receipt of Sample	23.09.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	23.09.2025	Date of Completion of Analysis	29.09.2025

Stack Details	
Stack Identity	Boiler Unit No. 3
Stack attached to	ESP of Boiler Unit No. 3
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	112
Load at the time of monitoring (MW)	155
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Flue gas Temperature	^0C	123	-	IS 11255 (Part 3):2008
2.	Flue gas Velocity	m/s	26.2	-	IS 11255 (Part 3):2008
3.	Flue gas Flow Rate	Nm^3/h	1082793	-	IS 11255 (Part 3):2008
4.	Particulate Matter (PM)	mg/Nm^3	39	50	IS 11255 (Part 1):1985
5.	Sulphur Dioxide (SO_2)	mg/Nm^3	560	600	IS 11255 (Part 2):1985
6.	Oxides of Nitrogen (NO_X)	mg/Nm^3	283	450	IS 11255 (Part 7): 2005
7.	Carbon Monoxide (CO)	mg/Nm^3	15	-	IS 5182 (Part 10): 1999 (NDIR method)

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1603250923

Report No.:	ME-1603250923	Date: 29.09.2025
ULR No.:	TC748725000017727F	

END OF REPORT

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. #: Limit as per MPCB Consent
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1604250923

Report No.:	ME-1604250923	Date: 29.09.2025
ULR No.:	TC748725000017728F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Stack Emission	Sampling Done by	Laboratory
Sampling Location	Boiler Unit No. 5	Sample Quantity / Packing	Thimble: 1 X 1 No. SO_2:30 mL X 1 No. PVC Bottle NO_X:25 mL X 1 No. PVC Bottle CO: 1L X 1 No. Gas Bladder
Date of Sampling	22.09.2025	Date of Receipt of Sample	23.09.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	23.09.2025	Date of Completion of Analysis	29.09.2025

Stack Details	
Stack Identity	Boiler Unit No. 5
Stack attached to	ESP of Boiler Unit No. 5
Material of construction	M.S.
Stack height above ground level (Meter)	275
Stack diameter (Meter)	4.6
Stack shape at top	Round
Type of fuel	Coal
Fuel Consumption (t/h)	105
Load at the time of monitoring (MW)	149
Time of Monitoring (h)	-

Sr. No.	Parameter	Unit	Result	#Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Stack Emission)				
1.	Flue gas Temperature	^0C	119	-	IS 11255 (Part 3):2008
2.	Flue gas Velocity	m/s	26.3	-	IS 11255 (Part 3):2008
3.	Flue gas Flow Rate	Nm^3/h	1112773	-	IS 11255 (Part 3):2008
4.	Particulate Matter (PM)	mg/Nm^3	39	50	IS 11255 (Part 1):1985
5.	Sulphur Dioxide (SO_2)	mg/Nm^3	511	600	IS 11255 (Part 2):1985
6.	Oxides of Nitrogen (NO_X)	mg/Nm^3	267	450	IS 11255 (Part 7): 2005
7.	Carbon Monoxide (CO)	mg/Nm^3	12	-	IS 5182 (Part 10): 1999 (NDIR method)

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SA-1604250923

Report No.:	ME-1604250923	Date: 29.09.2025
ULR No.:	TC748725000017728F	

END OF REPORT

Note:
1. BQL: Below Quantification Limit
2. LOQ: Limit of Quantification
3. #: Limit as per MPCB Consent
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1597250923

Report No.:	ME-1597250923	Date: 03.10.2025
ULR No.:	TC748725000017878F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ambient Air	Sampling Done by	Laboratory
Sampling Location	Village Kapustalni	Sample Quantity / Packing	PM_{10}, B(a), Ni, As, Pb: Filter Paper 1 X 3 No. $PM_{2.5}$: Filter Paper 1 X 1 No. SO_2:30 mL X 6 No. PVC Bottle NO_2:30 mL X 6 No. PVC Bottle NH_3:10 mL X 24 No. PVC Bottle O_3:10 mL X 24 No. PVC Bottle Charcoal Tubes: 1 X 6 No. CO:2L X 3No. Gas Bladder
Date of Sampling	22.09.2025 to 23.09.2025	Date of Receipt of Sample	23.09.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	23.09.2025	Date of Completion of Analysis	02.10.2025

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Ambient Air)				
1	Sulphur Dioxide (SO_2)	µg/m³	11.1	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.1-6
2	Nitrogen Dioxide (NO_2)	µg/m³	14.4	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.7-10
3	Particulate Matter (size less than 10µm) or PM_{10}	µg/m³	39	100	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.11-14
4	Particulate Matter (size less than 2.5µm) or $PM_{2.5}$	µg/m³	24	60	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.15-30
5	Ozone (O_3)	µg/m³	BQL (LOQ:19.6)	180	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.31-34

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1597250923

Report No.:	ME-1597250923	Date: 03.10.2025
ULR No.:	TC748725000017878F	

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
6	Lead (as Pb)	µg/m³	BQL (LOQ:0.02)	01	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999
7	Carbon Monoxide (CO)	mg/m³	0.99	04	CPCB Guidelines for the Measurement of Ambient Air Pollutants Volume-II, 2012-13, Page No. 16-22, (NDIR method)
8	Ammonia (NH_3)	µg/m³	21.3	400	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.35-39
9	Benzene (C_6H_6)	µg/m³	BQL (LOQ:1)	05	IS 5182 (Part 11): 2006
10	Benzo(a)Pyrene (Particulate phase only)	ng/m³	BQL (LOQ:0.5)	01	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.40-47
11	Arsenic (as As)	ng/m³	BQL (LOQ:0.3)	06	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999
12	Nickel (as Ni)	ng/m³	BQL (LOQ:3)	20	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. TWA: Time Weighted Average
4. Duration of Sampling: 24 h
5. NAAQS: National Ambient Air Quality Standard
6. #- NAAQS specified as: 24 h. TWA in case of Sulphur Dioxide, Nitrogen Dioxide, PM_{10}, $PM_{2.5}$, Lead and Ammonia; 1 h. TWA in case of Carbon Monoxide, Ozone; Annual TWA in case of Benzene, Benzo (a) Pyrene, Arsenic and Nickel.
7. The result listed refers only to the tested sample(s) and applicable parameter(s).
8. This report is not to be reproduced except in full, without the written approval of the laboratory.
9. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1598250923

Report No.:	ME-1598250923	Date: 03.10.2025
ULR No.:	TC748725000017879F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ambient Air	Sampling Done by	Laboratory
Sampling Location	Village Dawargaon	Sample Quantity / Packing	PM_{10}, B(a), Ni, As, Pb: Filter Paper 1 X 3 No. $PM_{2.5}$: Filter Paper 1 X 1 No. SO_2:30 mL X 6 No. PVC Bottle NO_2:30 mL X 6 No. PVC Bottle NH_3:10 mL X 24 No. PVC Bottle O_3:10 mL X 24 No. PVC Bottle Charcoal Tubes: 1 X 6 No. CO:2L X 3No. Gas Bladder
Date of Sampling	22.09.2025 to 23.09.2025	Date of Receipt of Sample	23.09.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	23.09.2025	Date of Completion of Analysis	02.10.2025

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Ambient Air)				
1	Sulphur Dioxide (SO_2)	µg/m³	13.6	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.1-6
2	Nitrogen Dioxide (NO_2)	µg/m³	15.7	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.7-10
3	Particulate Matter (size less than 10µm) or PM_{10}	µg/m³	45	100	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.11-14
4	Particulate Matter (size less than 2.5µm) or $PM_{2.5}$	µg/m³	24	60	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.15-30
5	Ozone (O_3)	µg/m³	BQL (LOQ:19.6)	180	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.31-34

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1598250923

Report No.:	ME-1598250923	Date: 03.10.2025
ULR No.:	TC748725000017879F	

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
6	Lead (as Pb)	µg/m³	BQL (LOQ:0.02)	01	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999
7	Carbon Monoxide (CO)	mg/m³	1.02	04	CPCB Guidelines for the Measurement of Ambient Air Pollutants Volume-II, 2012-13, Page No. 16-22, (NDIR method)
8	Ammonia (NH_3)	µg/m³	BQL (LOQ:20)	400	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.35-39
9	Benzene (C_6H_6)	µg/m³	BQL (LOQ:1)	05	IS 5182 (Part 11): 2006
10	Benzo(a)Pyrene (Particulate phase only)	ng/m³	BQL (LOQ:0.5)	01	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.40-47
11	Arsenic (as As)	ng/m³	BQL (LOQ:0.3)	06	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999
12	Nickel (as Ni)	ng/m³	BQL (LOQ:3)	20	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. TWA: Time Weighted Average
4. Duration of Sampling: 24 h
5. NAAQS: National Ambient Air Quality Standard
6. #- NAAQS specified as: 24 h. TWA in case of Sulphur Dioxide, Nitrogen Dioxide, PM_{10}, $PM_{2.5}$, Lead and Ammonia; 1 h. TWA in case of Carbon Monoxide, Ozone; Annual TWA in case of Benzene, Benzo (a) Pyrene, Arsenic and Nickel.
7. The result listed refers only to the tested sample(s) and applicable parameter(s).
8. This report is not to be reproduced except in full, without the written approval of the laboratory.
9. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1599250923

Report No.:	ME-1599250923	Date: 03.10.2025
ULR No.:	TC748725000017880F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ambient Air	Sampling Done by	Laboratory
Sampling Location	Village Wagholi Gate	Sample Quantity / Packing	PM_{10}, B(a), Ni, As, Pb: Filter Paper 1 X 3 No. $PM_{2.5}$: Filter Paper 1 X 1 No. SO_2:30 mL X 6 No. PVC Bottle NO_2:30 mL X 6 No. PVC Bottle NH_3:10 mL X 24 No. PVC Bottle O_3:10 mL X 24 No. PVC Bottle Charcoal Tubes: 1 X 6 No. CO:2L X 3No. Gas Bladder
Date of Sampling	22.09.2025 to 23.09.2025	Date of Receipt of Sample	23.09.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	23.09.2025	Date of Completion of Analysis	02.10.2025

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Ambient Air)				
1	Sulphur Dioxide (SO_2)	µg/m³	9.4	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.1-6
2	Nitrogen Dioxide (NO_2)	µg/m³	12.5	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.7-10
3	Particulate Matter (size less than 10µm) or PM_{10}	µg/m³	38	100	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.11-14
4	Particulate Matter (size less than 2.5µm) or $PM_{2.5}$	µg/m³	21	60	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.15-30
5	Ozone (O_3)	µg/m³	20.0	180	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.31-34

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1599250923

Report No.:	ME-1599250923	Date: 03.10.2025
ULR No.:	TC748725000017880F	

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
6	Lead (as Pb)	µg/m³	BQL (LOQ:0.02)	01	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999
7	Carbon Monoxide (CO)	mg/m³	0.75	04	CPCB Guidelines for the Measurement of Ambient Air Pollutants Volume-II, 2012-13, Page No. 16-22, (NDIR method)
8	Ammonia (NH_3)	µg/m³	23.2	400	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.35-39
9	Benzene (C_6H_6)	µg/m³	BQL (LOQ:1)	05	IS 5182 (Part 11): 2006
10	Benzo(a)Pyrene (Particulate phase only)	ng/m³	BQL (LOQ:0.5)	01	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.40-47
11	Arsenic (as As)	ng/m³	BQL (LOQ:0.3)	06	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999
12	Nickel (as Ni)	ng/m³	BQL (LOQ:3)	20	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. TWA: Time Weighted Average
4. Duration of Sampling: 24 h
5. NAAQS: National Ambient Air Quality Standard
6. #- NAAQS specified as: 24 h. TWA in case of Sulphur Dioxide, Nitrogen Dioxide, PM_{10}, $PM_{2.5}$, Lead and Ammonia; 1 h. TWA in case of Carbon Monoxide, Ozone; Annual TWA in case of Benzene, Benzo (a) Pyrene, Arsenic and Nickel.
7. The result listed refers only to the tested sample(s) and applicable parameter(s).
8. This report is not to be reproduced except in full, without the written approval of the laboratory.
9. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1600250923

Report No.:	ME-1600250923	Date: 03.10.2025
ULR No.:	TC748725000017881F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ambient Air	Sampling Done by	Laboratory
Sampling Location	Terrace of Bachelor Guest House	Sample Quantity / Packing	PM_{10}, B(a), Ni, As, Pb: Filter Paper 1 X 3 No. $PM_{2.5}$: Filter Paper 1 X 1 No. SO_2:30 mL X 6 No. PVC Bottle NO_2:30 mL X 6 No. PVC Bottle NH_3:10 mL X 24 No. PVC Bottle O_3:10 mL X 24 No. PVC Bottle Charcoal Tubes: 1 X 6 No. CO:2L X 3No. Gas Bladder
Date of Sampling	22.09.2025 to 23.09.2025	Date of Receipt of Sample	23.09.2025
Sampling Procedure	As per method reference		
Date of Start of Analysis	23.09.2025	Date of Completion of Analysis	02.10.2025

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Ambient Air)				
1	Sulphur Dioxide (SO_2)	µg/m³	12.6	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.1-6
2	Nitrogen Dioxide (NO_2)	µg/m³	18.1	80	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.7-10
3	Particulate Matter (size less than 10µm) or PM_{10}	µg/m³	59	100	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.11-14
4	Particulate Matter (size less than 2.5µm) or $PM_{2.5}$	µg/m³	31	60	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.15-30
5	Ozone (O_3)	µg/m³	20.3	180	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.31-34

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

AA-1600250923

Report No.:	ME-1600250923	Date: 03.10.2025
ULR No.:	TC748725000017881F	

Sr. No.	Parameter	Unit	Result	#NAAQS	Method Reference
6	Lead (as Pb)	µg/m³	BQL (LOQ:0.02)	01	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999
7	Carbon Monoxide (CO)	mg/m³	0.83	04	CPCB Guidelines for the Measurement of Ambient Air Pollutants Volume-II, 2012-13, Page No. 16-22, (NDIR method)
8	Ammonia (NH_3)	µg/m³	21.9	400	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.35-39
9	Benzene (C_6H_6)	µg/m³	BQL (LOQ:1)	05	IS 5182 (Part 11): 2006
10	Benzo(a)Pyrene (Particulate phase only)	ng/m³	BQL (LOQ:0.5)	01	CPCB Guidelines for the Measurement of Ambient Air Pollutants, Volume I, 2012-13, Page No.40-47
11	Arsenic (as As)	ng/m³	BQL (LOQ:0.3)	06	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999
12	Nickel (as Ni)	ng/m³	BQL (LOQ:3)	20	USEPA/625/R-96/010a Compendium Method IO-3.1 & 3.4: 1999

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. TWA: Time Weighted Average
4. Duration of Sampling: 24 h
5. NAAQS: National Ambient Air Quality Standard
6. #- NAAQS specified as: 24 h. TWA in case of Sulphur Dioxide, Nitrogen Dioxide, PM_{10}, $PM_{2.5}$, Lead and Ammonia; 1 h. TWA in case of Carbon Monoxide, Ozone; Annual TWA in case of Benzene, Benzo (a) Pyrene, Arsenic and Nickel.
7. The result listed refers only to the tested sample(s) and applicable parameter(s).
8. This report is not to be reproduced except in full, without the written approval of the laboratory.
9. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

WNA-1605250923

Report No.:	ME-1605250923	Date: 29.09.2025
ULR No.:	TC748725000017729F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**	SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Workroom Noise	
Date of Sampling	23.09.2025	
Sampling Procedure	CPCB Protocol for Ambient level Noise Monitoring 2015	

Sr. No.	Location	Time in h	Sound Level L_{eq} dB (A)	
			L_{min}	L_{max}
	Discipline: Chemical Testing; Product Group: Atmospheric Pollution (Workroom Noise)			
1.	Turbine Area No. 3 & 4	10:00 to 10:05	66.8	71.5
2.	Near CHP Crusher House	10:40 to 10:45	62.4	68.9
3.	Near Compressor Room	11:10 to 11:15	64.4	69.7
4.	Near Main Gate	11:40 to 11:45	61.7	65.2
5.	Near Colony	12:20 to 12:25	56.7	61.9

Limit as per The Factories Act, 1948, The Maharashtra Factory Rules, 1963, Schedule XXIV	
Total time of exposure per day, in hours.	**Max. Sound pressure level in dB (A)**
8	90
6	92
4	95
3	97
2	100
1 ½	102
1	105
¾	107
½	110
¼	115

END OF REPORT

Note:
1. The result listed refers only to the tested sample(s) and applicable parameter(s).
2. This report is not to be reproduced except in full, without the written approval of the laboratory.
3. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

DE-1619250923

Report No.:	ME-1619250923	Date: 03.10.2025
ULR No.:	TC748725000017895F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Domestic Effluent	Sampling Done by	Laboratory
Sampling Location	Colony STP Outlet	Sample Quantity / Packing	2 L X 1 No. PVC Can 250mL X 1 No. PVC Can
Date of Sampling	23.09.2025	Date of Receipt of Sample	23.09.2025
Sampling Procedure	IS 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	23.09.2025	Date of Completion of Analysis	03.10.2025

Sr. No.	Parameter	Unit	Result	# Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Pollution & Environment (Waste Water)				
1.	pH	-	8.3	6.5 to 8.5	APHA 24th Ed. 2023, 4500-H^+-B
2.	Biochemical Oxygen Demand (3 days 27°C)	mg/L	8.2	30 Max.	IS 3025 (Part 44):2023
3.	Chemical Oxygen Demand	mg/L	31	250 Max.	APHA 24th Ed. 2023, 5220-B

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. #: Limit as per MPCB Consent.
4. The result listed refers only to the tested sample(s) and applicable parameter(s).
5. This report is not to be reproduced except in full, without the written approval of the laboratory.
6. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P.LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SW-1606250923

Report No.:	ME-1606250923	Date: 03.10.2025
ULR No.:	TC748725000017882F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Surface water	Sampling Done by	Laboratory
Sampling Location	Malegaon Pond	Sample Quantity / Packing	2L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	23.09.2025	Date of Receipt of Sample	23.09.2025
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	23.09.2025	Date of Completion of Analysis	03.10.2025

Sr. No.	Parameter	Unit	Result	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Surface Water)			
1.	Colour	Hazen	BQL (LOQ:1)	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.1	APHA 24th Ed. 2023, 2130-B
4.	pH	-	8.0	APHA 24th Ed. 2023, 4500-H+-B
5.	Free Chlorine (Residual)	mg/L	BQL (LOQ:0.05)	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids	mg/L	565	IS 3025 (Part 16):2023
7.	Total Suspended Solids	mg/L	BQL (LOQ:5)	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	166	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	402	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	88.0	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	180	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	1.10	APHA 24th Ed. 2023,4500-NO_3, E
13.	Calcium (as Ca)	mg/L	100	APHA 24th Ed. 2023, 3500-Ca-B
14.	Magnesium (as Mg)	mg/L	36.9	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.68	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.1	APHA 24th Ed. 2023, 4500-O, B & C
17.	Oil and Grease	mg/L	BQL (LOQ:1)	IS 3025 (Part 39): 2021

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SW-1606250923

Report No.:	ME-1606250923	Date: 03.10.2025
ULR No.:	TC748725000017882F	

Sr. No.	Parameter	Unit	Result	Method Reference
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water			
20.	Boron (as B)	mg/L	0.141	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.149	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	0.037	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	BQL (LOQ:0.02)	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. The result listed refers only to the tested sample(s) and applicable parameter(s).
4. This report is not to be reproduced except in full, without the written approval of the laboratory.
5. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

SW-1607250923

TEST REPORT

Report No.:	ME-1607250923	Date: 03.10.2025
ULR No.:	TC748725000017883F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Surface water	Sampling Done by	Laboratory
Sampling Location	Wagholi Pond	Sample Quantity / Packing	2L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	23.09.2025	Date of Receipt of Sample	23.09.2025
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	23.09.2025	Date of Completion of Analysis	03.10.2025

Sr. No.	Parameter	Unit	Result	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Surface Water)			
1.	Colour	Hazen	BQL (LOQ:1)	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.3	APHA 24th Ed. 2023, 2130-B
4.	pH	-	7.9	APHA 24th Ed. 2023, 4500-H+-B
5.	Free Chlorine (Residual)	mg/L	BQL (LOQ:0.05)	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids	mg/L	560	IS 3025 (Part 16):2023
7.	Total Suspended Solids	mg/L	BQL (LOQ:5)	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	164	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	402	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	86.5	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	173	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	1.53	APHA 24th Ed. 2023,4500-NO_3, E
13.	Calcium (as Ca)	mg/L	97.8	APHA 24th Ed. 2023, 3500-Ca-B
14.	Magnesium (as Mg)	mg/L	38.4	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.82	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.0	APHA 24th Ed. 2023, 4500-O, B & C
17.	Oil and Grease	mg/L	BQL (LOQ:1)	IS 3025 (Part 39): 2021

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

SW-1607250923

Report No.:	ME-1607250923	Date: 03.10.2025
ULR No.:	TC748725000017883F	

Sr. No.	Parameter	Unit	Result	Method Reference
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water			
20.	Boron (as B)	mg/L	0.026	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.063	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	BQL (LOQ:0.01)	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	BQL (LOQ:0.02)	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. The result listed refers only to the tested sample(s) and applicable parameter(s).
4. This report is not to be reproduced except in full, without the written approval of the laboratory.
5. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1608250923

Report No.:	ME-1608250923	Date: 03.10.2025
ULR No.:	TC748725000017884F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ground water	Sampling Done by	Laboratory
Sampling Location	Village Pimpalvihirgaon	Sample Quantity / Packing	2L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	23.09.2025	Date of Receipt of Sample	23.09.2025
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	23.09.2025	Date of Completion of Analysis	03.10.2025

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Ground Water)					
1.	Colour	Hazen	BQL (LOQ:1)	5 Max.	15 Max.	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.3	1 Max.	5 Max.	APHA 24th Ed. 2023, 2130-B
4.	pH	-	7.6	6.5 to 8.5	No relaxation	APHA 24th Ed. 2023, 4500-H+-B
5.	Free Chlorine (Residual)	mg/L	BQL (LOQ:0.05)	0.2 Min.	1.0 Max.	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids	mg/L	515	500 Max.	2000 Max.	IS 3025 (Part 16):2023
7.	Total Suspended Solids	mg/L	BQL (LOQ:5)	-	-	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	280	200 Max.	600 Max.	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	374	200 Max.	600 Max.	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	31.5	250 Max.	1000 Max.	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	86.6	200 Max.	400 Max.	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	36.9	45 Max.	No relaxation	APHA 24th Ed. 2023,4500-NO_3, B
13.	Calcium (as Ca)	mg/L	101	75 Max.	200 Max.	APHA 24th Ed. 2023, 3500-Ca-B

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1608250923

Report No.:	ME-1608250923	Date: 03.10.2025
ULR No.:	TC748725000017884F	

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
14.	Magnesium (as Mg)	mg/L	29.6	30 Max.	100 Max.	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.74	1 Max.	1.5 Max.	APHA 24th Ed. 2023, 4500 F, D
16.	Dissolved Oxygen	mg/L	6.2	-	-	APHA 24th Ed. 2023, 4500-O, B & C
17.	Oil and Grease	mg/L	BQL (LOQ:1)	-	-	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	0.05 Max.	No relaxation	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	0.001 Max.	0.002 Max.	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water					
20.	Boron (as B)	mg/L	0.027	0.5 Max.	2.4 Max.	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.077	1.0 Max.	No relaxation	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	BQL (LOQ:0.01)	0.1 Max.	0.3 Max.	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	0.03 Max.	0.2 Max.	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	0.003Max	No relaxation	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	0.05 Max.	No relaxation	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	0.05 Max.	1.5 Max.	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	BQL (LOQ:0.02)	5 Max.	15 Max.	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	0.001Max	No relaxation	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. # Acceptable Limit as per IS 10500:2012
4. $ Permissible Limit in the Absence of Alternate Source as per IS 10500:2012
5. The result listed refers only to the tested sample(s) and applicable parameter(s).
6. This report is not to be reproduced except in full, without the written approval of the laboratory.
7. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1609250923

Report No.:	ME-1609250923	Date: 03.10.2025
ULR No.:	TC748725000017885F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ground water	Sampling Done by	Laboratory
Sampling Location	Village Dawargaon	Sample Quantity / Packing	2L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	23.09.2025	Date of Receipt of Sample	23.09.2025
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	23.09.2025	Date of Completion of Analysis	03.10.2025

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Ground Water)					
1.	Colour	Hazen	BQL (LOQ:1)	5 Max.	15 Max.	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.5	1 Max.	5 Max.	APHA 24th Ed. 2023, 2130-B
4.	pH	-	7.8	6.5 to 8.5	No relaxation	APHA 24th Ed. 2023, 4500-H+-B
5.	Free Chlorine (Residual)	mg/L	BQL (LOQ:0.05)	0.2 Min.	1.0 Max.	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids	mg/L	621	500 Max.	2000 Max.	IS 3025 (Part 16):2023
7.	Total Suspended Solids	mg/L	BQL (LOQ:5)	-	-	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	186	200 Max.	600 Max.	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	462	200 Max.	600 Max.	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	81.5	250 Max.	1000 Max.	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	176	200 Max.	400 Max.	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	19.3	45 Max.	No relaxation	APHA 24th Ed. 2023,4500-NO_3, B
13.	Calcium (as Ca)	mg/L	116	75 Max.	200 Max.	APHA 24th Ed. 2023, 3500-Ca-B

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1609250923

Report No.:	ME-1609250923	Date: 03.10.2025
ULR No.:	TC748725000017885F	

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
14.	Magnesium (as Mg)	mg/L	41.8	30 Max.	100 Max.	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.69	1 Max.	1.5 Max.	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.3	-	-	APHA 24th Ed. 2023, 4500-O, B & C
17.	Oil and Grease	mg/L	BQL (LOQ:1)	-	-	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	0.05 Max.	No relaxation	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	0.001 Max.	0.002 Max.	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water					
20.	Boron (as B)	mg/L	BQL (LOQ:0.02)	0.5 Max.	2.4 Max.	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.391	1.0 Max.	No relaxation	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	BQL (LOQ:0.01)	0.1 Max.	0.3 Max.	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	0.03 Max.	0.2 Max.	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	0.003Max	No relaxation	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	0.05 Max.	No relaxation	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	0.05 Max.	1.5 Max.	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	BQL (LOQ:0.02)	5 Max.	15 Max.	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	0.001Max	No relaxation	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. # Acceptable Limit as per IS 10500:2012
4. $ Permissible Limit in the Absence of Alternate Source as per IS 10500:2012
5. The result listed refers only to the tested sample(s) and applicable parameter(s).
6. This report is not to be reproduced except in full, without the written approval of the laboratory.
7. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

GW-1610250923

TEST REPORT

Report No.:	ME-1610250923	Date: 03.10.2025
ULR No.:	TC748725000017886F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ground water	Sampling Done by	Laboratory
Sampling Location	Village Talkhanda	Sample Quantity / Packing	2L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	23.09.2025	Date of Receipt of Sample	23.09.2025
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	23.09.2025	Date of Completion of Analysis	03.10.2025

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Ground Water)					
1.	Colour	Hazen	BQL (LOQ:1)	5 Max.	15 Max.	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.3	1 Max.	5 Max.	APHA 24th Ed. 2023, 2130-B
4.	pH	-	7.6	6.5 to 8.5	No relaxation	APHA 24th Ed. 2023, 4500-H+-B
5.	Free Chlorine (Residual)	mg/L	BQL (LOQ:0.05)	0.2 Min.	1.0 Max.	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids	mg/L	498	500 Max.	2000 Max.	IS 3025 (Part 16):2023
7.	Total Suspended Solids	mg/L	BQL (LOQ:5)	-	-	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	300	200 Max.	600 Max.	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	358	200 Max.	600 Max.	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	37.5	250 Max.	1000 Max.	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	46.7	200 Max.	400 Max.	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	37.0	45 Max.	No relaxation	APHA 24th Ed. 2023,4500-NO_3, B
13.	Calcium (as Ca)	mg/L	82.6	75 Max.	200 Max.	APHA 24th Ed. 2023, 3500-Ca-B

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1610250923

Report No.:	ME-1610250923	Date: 03.10.2025
ULR No.:	TC748725000017886F	

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
14.	Magnesium (as Mg)	mg/L	36.9	30 Max.	100 Max.	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.64	1 Max.	1.5 Max.	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.2	-	-	APHA 24th Ed. 2023, 4500-O, B & C
17.	Oil and Grease	mg/L	BQL (LOQ:1)	-	-	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	0.05 Max.	No relaxation	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	0.001 Max.	0.002 Max.	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water					
20.	Boron (as B)	mg/L	0.028	0.5 Max.	2.4 Max.	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.119	1.0 Max.	No relaxation	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	BQL (LOQ:0.01)	0.1 Max.	0.3 Max.	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	0.03 Max.	0.2 Max.	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	0.003Max	No relaxation	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	0.05 Max.	No relaxation	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	0.05 Max.	1.5 Max.	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	BQL (LOQ:0.02)	5 Max.	15 Max.	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	0.001Max	No relaxation	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. # Acceptable Limit as per IS 10500:2012
4. $ Permissible Limit in the Absence of Alternate Source as per IS 10500:2012
5. The result listed refers only to the tested sample(s) and applicable parameter(s).
6. This report is not to be reproduced except in full, without the written approval of the laboratory.
7. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1611250923

Report No.:	ME-1611250923	Date: 03.10.2025
ULR No.:	TC748725000017887F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ground water	Sampling Done by	Laboratory
Sampling Location	Backside of Ash dyke Area Mr. N. Lomte Farm	Sample Quantity / Packing	2L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	23.09.2025	Date of Receipt of Sample	23.09.2025
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	23.09.2025	Date of Completion of Analysis	03.10.2025

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Ground Water)					
1.	Colour	Hazen	BQL (LOQ:1)	5 Max.	15 Max.	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.3	1 Max.	5 Max.	APHA 24th Ed. 2023, 2130-B
4.	pH	-	7.7	6.5 to 8.5	No relaxation	APHA 24th Ed. 2023, 4500-H+-B
5.	Free Chlorine (Residual)	mg/L	BQL (LOQ:0.05)	0.2 Min.	1.0 Max.	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids	mg/L	529	500 Max.	2000 Max.	IS 3025 (Part 16):2023
7.	Total Suspended Solids	mg/L	BQL (LOQ:5)	-	-	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	332	200 Max.	600 Max.	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	376	200 Max.	600 Max.	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	34.0	250 Max.	1000 Max.	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	45.3	200 Max.	400 Max.	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	39.7	45 Max.	No relaxation	APHA 24th Ed. 2023,4500-NO_3, B
13.	Calcium (as Ca)	mg/L	104	75 Max.	200 Max.	APHA 24th Ed. 2023, 3500-Ca-B

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1611250923

Report No.:	ME-1611250923	Date: 03.10.2025
ULR No.:	TC748725000017887F	

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
14.	Magnesium (as Mg)	mg/L	28.2	30 Max.	100 Max.	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.54	1 Max.	1.5 Max.	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.1	-	-	APHA 24th Ed. 2023, 4500-O, B & C
17.	Oil and Grease	mg/L	BQL (LOQ:1)	-	-	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	0.05 Max.	No relaxation	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	0.001 Max.	0.002 Max.	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water					
20.	Boron (as B)	mg/L	0.025	0.5 Max.	2.4 Max.	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.143	1.0 Max.	No relaxation	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	BQL (LOQ:0.01)	0.1 Max.	0.3 Max.	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	0.03 Max.	0.2 Max.	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	0.003Max	No relaxation	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	0.05 Max.	No relaxation	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	0.05 Max.	1.5 Max.	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	BQL (LOQ:0.02)	5 Max.	15 Max.	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	0.001Max	No relaxation	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. # Acceptable Limit as per IS 10500:2012
4. $ Permissible Limit in the Absence of Alternate Source as per IS 10500:2012
5. The result listed refers only to the tested sample(s) and applicable parameter(s).
6. This report is not to be reproduced except in full, without the written approval of the laboratory.
7. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1612250923

Report No.:	ME-1612250923	Date: 03.10.2025
ULR No.:	TC748725000017888F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ground water	Sampling Done by	Laboratory
Sampling Location	Village Kapustalni	Sample Quantity / Packing	2L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	23.09.2025	Date of Receipt of Sample	23.09.2025
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	23.09.2025	Date of Completion of Analysis	03.10.2025

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Ground Water)					
1.	Colour	Hazen	BQL (LOQ:1)	5 Max.	15 Max.	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.3	1 Max.	5 Max.	APHA 24th Ed. 2023, 2130-B
4.	pH	-	7.6	6.5 to 8.5	No relaxation	APHA 24th Ed. 2023, 4500-H+-B
5.	Free Chlorine (Residual)	mg/L	BQL (LOQ:0.05)	0.2 Min.	1.0 Max.	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids	mg/L	472	500 Max.	2000 Max.	IS 3025 (Part 16):2023
7.	Total Suspended Solids	mg/L	BQL (LOQ:5)	-	-	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	278	200 Max.	600 Max.	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	362	200 Max.	600 Max.	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	30.0	250 Max.	1000 Max.	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	47.2	200 Max.	400 Max.	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	37.1	45 Max.	No relaxation	APHA 24th Ed. 2023,4500-NO_3, B
13.	Calcium (as Ca)	mg/L	94.6	75 Max.	200 Max.	APHA 24th Ed. 2023, 3500-Ca-B

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1612250923

Report No.:	ME-1612250923	Date: 03.10.2025
ULR No.:	TC748725000017888F	

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
14.	Magnesium (as Mg)	mg/L	30.6	30 Max.	100 Max.	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.63	1 Max.	1.5 Max.	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.3	-	-	APHA 24th Ed. 2023, 4500-O, B & C
17.	Oil and Grease	mg/L	BQL (LOQ:1)	-	-	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	0.05 Max.	No relaxation	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	0.001 Max.	0.002 Max.	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water					
20.	Boron (as B)	mg/L	0.026	0.5 Max.	2.4 Max.	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.142	1.0 Max.	No relaxation	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	BQL (LOQ:0.01)	0.1 Max.	0.3 Max.	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	0.03 Max.	0.2 Max.	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	0.003Max	No relaxation	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	0.05 Max.	No relaxation	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	0.05 Max.	1.5 Max.	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	BQL (LOQ:0.02)	5 Max.	15 Max.	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	0.001Max	No relaxation	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. # Acceptable Limit as per IS 10500:2012
4. $ Permissible Limit in the Absence of Alternate Source as per IS 10500:2012
5. The result listed refers only to the tested sample(s) and applicable parameter(s).
6. This report is not to be reproduced except in full, without the written approval of the laboratory.
7. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS PVT. LTD. Laboratory Division

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1613250923

Report No.:	ME-1613250923	Date: 03.10.2025
ULR No.:	TC748725000017889F	

Name and Address of Customer	**RATTANINDIA POWER LIMITED Plot No. D-2 & D-2 (PART) at Additional MIDC, Village-Nandgaonpeth, Tal & Dist: Amravati 444 901**		SO No.: 3382026036 SO Date: 25.03.2025
Sample Description / Type	Ground water	Sampling Done by	Laboratory
Sampling Location	Village Wagholi	Sample Quantity / Packing	2L X 1 No. PVC Can 500 mL X 1 No. PVC Can 1 L X 1 No. Glass Bottle
Date of Sampling	23.09.2025	Date of Receipt of Sample	23.09.2025
Sampling Procedure	IS: 17614; APHA 24th Ed. 2023, 1060-B		
Date of Start of Analysis	23.09.2025	Date of Completion of Analysis	03.10.2025

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
	Discipline: Chemical Testing; Product Group: Water (Ground Water)					
1.	Colour	Hazen	BQL (LOQ:1)	5 Max.	15 Max.	APHA 24th Ed. 2023, 2120-B
2.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 05):2018
3.	Turbidity	NTU	0.2	1 Max.	5 Max.	APHA 24th Ed. 2023, 2130-B
4.	pH	-	7.7	6.5 to 8.5	No relaxation	APHA 24th Ed. 2023, 4500-H+-B
5.	Free Chlorine (Residual)	mg/L	BQL (LOQ:0.05)	0.2 Min.	1.0 Max.	APHA 24th Ed. 2023, 4500-Cl G
6.	Total Dissolved Solids	mg/L	615	500 Max.	2000 Max.	IS 3025 (Part 16):2023
7.	Total Suspended Solids	mg/L	BQL (LOQ:5)	-	-	APHA 24th Ed. 2023, 2540-D
8.	Alkalinity Total (as $CaCO_3$)	mg/L	194	200 Max.	600 Max.	APHA 24th Ed. 2023, 2320-B
9.	Total Hardness (as $CaCO_3$)	mg/L	468	200 Max.	600 Max.	APHA 24th Ed. 2023, 2340-C
10.	Chloride (as Cl)	mg/L	87.0	250 Max.	1000 Max.	APHA 24th Ed. 2023, 4500-Cl-B
11.	Sulphate (as SO_4)	mg/L	176	200 Max.	400 Max.	APHA 24th Ed. 2023, 4500-SO_4-E
12.	Nitrate (as NO_3)	mg/L	19.2	45 Max.	No relaxation	APHA 24th Ed. 2023,4500-NO_3, B
13.	Calcium (as Ca)	mg/L	122	75 Max.	200 Max.	APHA 24th Ed. 2023, 3500-Ca-B

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

TC-7487

Mahabal Enviro Engineers Pvt. Ltd.

PLOT NOS. 13,14,17,18, GRAMPANCHAYAT BOKHARA, CHHINDWARA ROAD, KORADI, NAGPUR, MAHARASHTRA, INDIA
Phone: **0712-2612162/2612212** email: **nagpur@mahabal.com**

TEST REPORT

GW-1613250923

Report No.:	ME-1613250923	Date: 03.10.2025
ULR No.:	TC748725000017889F	

Sr. No.	Parameter	Unit	Result	#Limit	$Limit	Method Reference
14.	Magnesium (as Mg)	mg/L	39.9	30 Max.	100 Max.	APHA 24th Ed. 2023, 3500-Mg-B
15.	Fluoride (as F)	mg/L	0.54	1 Max.	1.5 Max.	APHA 24th Ed. 2023, 4500-F, D
16.	Dissolved Oxygen	mg/L	6.4	-	-	APHA 24th Ed. 2023, 4500-O, B & C
17.	Oil and Grease	mg/L	BQL (LOQ:1)	-	-	IS 3025 (Part 39): 2021
18.	Cyanide (as CN)	mg/L	BQL (LOQ:0.001)	0.05 Max.	No relaxation	APHA 24th Ed. 2023, 4500-CN, C & E
19.	Phenolic Compounds (as C_6H_5OH)	mg/L	BQL (LOQ:0.001)	0.001 Max.	0.002 Max.	APHA 24th Ed. 2023, 5530- B & C
	Product Group: Residues in water					
20.	Boron (as B)	mg/L	0.026	0.5 Max.	2.4 Max.	IS 3025 (Part 2) 2019
21.	Iron (as Fe)	mg/L	0.129	1.0 Max.	No relaxation	IS 3025 (Part 2) 2019
22.	Manganese (as Mn)	mg/L	BQL (LOQ:0.01)	0.1 Max.	0.3 Max.	IS 3025 (Part 2) 2019
23.	Aluminium (as Al)	mg/L	BQL (LOQ:0.025)	0.03 Max.	0.2 Max.	APHA 24th Ed. 2023, 3500-Al-B
24.	Cadmium (as Cd)	mg/L	BQL (LOQ:0.0027)	0.003Max	No relaxation	IS 3025 (Part 2) 2019
25.	Chromium Total (as Cr)	mg/L	BQL (LOQ:0.01)	0.05 Max.	No relaxation	IS 3025 (Part 2) 2019
26.	Copper (as Cu)	mg/L	BQL (LOQ:0.01)	0.05 Max.	1.5 Max.	IS 3025 (Part 2) 2019
27.	Lead (as Pb)	mg/L	BQL (LOQ:0.008)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
28.	Zinc (as Zn)	mg/L	BQL (LOQ:0.02)	5 Max.	15 Max.	IS 3025 (Part 2) 2019
29.	Arsenic (as As)	mg/L	BQL (LOQ:0.007)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019
30.	Mercury (as Hg)	mg/L	BQL (LOQ:0.0005)	0.001Max	No relaxation	APHA 24th Ed. 2023, 3112-B
31.	Selenium (as Se)	mg/L	BQL (LOQ:0.01)	0.01 Max.	No relaxation	IS 3025 (Part 2) 2019

END OF REPORT

Note:
1. BQL: Below Quantification Limit.
2. LOQ: Limit of Quantification.
3. # Acceptable Limit as per IS 10500:2012
4. $ Permissible Limit in the Absence of Alternate Source as per IS 10500:2012
5. The result listed refers only to the tested sample(s) and applicable parameter(s).
6. This report is not to be reproduced except in full, without the written approval of the laboratory.
7. Any complaint pertaining to the report can be addressed to mahabalreports@gmail.com

Reviewed and authorised by

Sagar Yeul
Dy.Technical Manager
Chemical Testing

MAHABAL ENVIRO ENGINEERS P.LTD. Laboratory Division

TC-7487