MAHARASHTRA POLLUTION CONTROL BOARD

Tel: 24010706/24010437
Fax: 24023516
Website: http://mpcb.gov.in
Email: cac-cell@mpcb.gov.in

Kalpataru Point, 2nd and 4th floor, Opp. Cine Planet Cinema, Near Sion Circle, Sion (E), Mumbai-400022

RED/L.S.I (R48)
No:- Format1.0/CAC/UAN No.MPCB-CONSENT-0000174987/CR/2310002155

Date: 28/10/2023

To,
M/s RattanIndia Power Ltd.,
Plot No.D-2 & D-2(Part), Additional Industrial Area,
MIDC Nandgaonpeth,Amravati,
Tal & Dist-Amravati.

Your Service is Our Duty

Sub: Renewal of consent with increase in C.I. under RED Category

Ref:
1. Environmental Clearance granted by the MoEF GoI vide letter No. J-13011/49/2008-IA II(T) dated 27.02.2009,dtd. 27.05.2011 and amendment vide dtd. 27.07.2021
2. Previous consent granted by the Board vide No.- Format1.0/CAC/UAN No.MPCBCONSENT-0000142510/CR/2211001095 dated 14/11/2022, valid up to 31.08.2023
3. The Minutes of Consent Appraisal Committee Meeting held on 26.09.2023.

Your application No.MPCB-CONSENT-0000174987 Dated 28.06.2023

For: Grant of Consent to Operate under Section 26 of the Water (Prevention & Control of Pollution) Act, 1974 & under Section 21 of the Air (Prevention & Control of Pollution) Act, 1981 and Authorization under Rule 6 and Rule 18(7) of the Hazardous & Other Wastes (Management & Transboundary Movement) Rules 2016 is considered and the consent is hereby granted subject to the following terms and conditions and as detailed in the schedule I, II, III & IV annexed to this order:

1. **The consent to renewal is granted for a period up to 31/12/2026**
2. **The capital investment of the project is Rs.8245.0236 Crs. (As per Balance Sheet submitted by industry Existing CI is Rs. 7587.05 Crs+ Increase in Rs. 657.9736 Crs)**
3. **Consent is valid for the manufacture of:**

Sr No	Product	Maximum Quantity	UOM
Products			
1	Electricity Generation (5 x 270 MW) (Phase-I)	1350	MW

4. **Conditions under Water (P&CP), 1974 Act for discharge of effluent:**

Sr No	Description	Permitted (in CMD)	Standards to	Disposal Path
1.	Trade effluent	24020	As per Schedule-I	Recycle/reused 100 % for Cooling tower,Dust suppresion and Ash handling plant etc.
2.	Domestic effluent	380	As per Schedule-I	On land for gardening

5. **Conditions under Air (P& CP) Act, 1981 for air emissions:**

Sr No.	Stack No.	Description of stack / source	Number of Stack	Standards to be achieved
1	S-1	Boiler No-1 & 2 (Bi-Flue Stack)	01	As per Schedule -II
2	S-2	Boiler No-3,4 & 5 (Tri-flue Stack)	01	As per Schedule -II
3	S-3 to S-7	DG Sets of 1010 KVA X2 Nos, 750x3 Nos	5	As per Schedule -II

6. **Non-Hazardous Wastes:**


Sr No	Type of Waste	Quantity	UoM	Treatment	Disposal
1	Fly Ash	2044374	MT/A	Recycle	Shall be sent to Cement Manufacturing Plant, Brick Manufacturing Plant and dispose as per MoEF & CC notification vide S.O. 5481(E) dtd.31.12.2021 & its amendment dtd.30.12.2022 & amendments thereafter.
2	Bottom Ash	511093	MT/A	Recycle	As per MoEF & CC notification vide S.O. 5481(E) dtd.31.12.2021 & its amendment dtd.30.12.2022 & amendments thereafter.

7. **Conditions under Hazardous & Other Wastes (M & T M) Rules 2016 for Collection, Segregation, Storage, Transportation, Treatment and Disposal of hazardous waste:**

Sr No	Category No./ Type	Quantity	UoM	Treatment	Disposal
1	5.1 Used or spent oil	100	Kg/Day	Recycle	send to authorised Re-procesors or Recycler
2	5.2 Wastes or residues containing oil	25	Kg/Day	Incineration	CHWTSDF
3	35.3 Chemical sludge from waste water treatment	50	Kg/Day	Secured Land Filling	CHWTSDF
4	Other HW	50	Kg/Day	Incineration	CHWTSDF

8. The Board reserves the right to review, amend, suspend, revoke this consent and the same shall be binding on the industry.
9. This consent should not be construed as exemption from obtaining necessary NOC/ permission from any other Government authorities.
10. PP shall comply with the conditions of the Environmental Clearance granted by MoEFCC, GoI time to time.
11. PP shall promote adoption of clean coal (with ash content less than 34%) and clean power generation technologies and comply with the notifications issued by MOEF for utilization of fly ash from coal or lignite based thermal power plants issued by time to time.
12. PP shall ensure to operate online continuous monitoring system as per CPCB guidelines & data to be transmitted directly from Data Logger to Board server.
13. PP shall comply with the recommendations of the task force implementation of CREP recommendations for thermal Power Plants.
14. PP shall comply the standards stipulated by the Ministry of Environment, Forest and Climate Change vide Notification dtd 07.12.2015. PP shall Operate and Maintain the APCS so as to achieve the emission Standards.
15. PP shall install and commission the FGD as per as per MOEFCC Gazette Notification No. G.S. R. 682(E) dtd.5.09.2022
16. PP shall submit the fortnight compliance progress report of action plan regarding the compliance to achieve the emission standards including installation of FGD system as per the MoEF & CC GoI notification dated 31.03.2021 & dtd.5.09.2022 to the respective Sub Regional Officer and Regional Officer.
17. PP shall be disposed of fly ash as per MoEF & CC noti?cation vide S.O. 5481(E) dtd.31.12.2021 & its amendment dtd.30.12.2022 & amendments thereafter. And shall achieve 100% utilization of Fly Ash. PP shall dispose legacy pond ash regularly. PP shall submit the action plan for disposal of Legacy pond ash within a month period.
18. The sulphur and ash content in the coal to be used in the project shall not exceed 0.5% and 34% respectively. PP shall not use high ash content coal (i.e more than 34%).

19. PP shall comply with the MoEF & CC amendment notification no. S.O.1561 (E) dtd. 21.05.2020. PP shall comply with the emission norms within the time limit as specified in MoEF & CC,GoI Notification dated 31.03.2021.
20. PP shall comply MOEF Office memorandum dtd 26.08.2015 by protocol for sampling, analysis of coal and reporting of compliance in respect of implementation of the Gazette Notification on use and supply of raw or blended of beneficiated coal with ash content not exceeding 34% on quarterly average basis.
21. PP shall submit/extend BG of Rs. 63.0 Lakh towards O & M of PCS and compliance of consent and EC conditions.
22. The applicant shall make an application for renewal of consent 60 days prior to date of expiry of the consent.



c6b43511
97465b4b
aecce4df
c969c140
7468df37
c2a80ea9
be52265b
5c3b975c

Signed by: Dr.Avinash Dhakne
Member Secretary
For and on behalf of,
Maharashtra Pollution Control Board
ms@mpcb.gov.in
2023-10-28 23:49:09 IST

Received Consent fee of -

Sr.No	Amount(Rs.)	Transaction/DR.No.	Date	Transaction Type
1	30355560.00	MPCB-DR-19844	30/06/2023	RTGS
2	38234678.00	MPCB-DR-21665	22/09/2023	RTGS

PP has paid Total fees of Rs. 30355560 + Rs.38234678+Rs. 15174100 (balance from previous consent)=Rs.83764338/-. Out of this, Rs. 56282775/- is used for this consent including fees for enhancement in C.I. and additional fees for 4 months period and Balance fees of Rs. 27481563/- will be considered for next renewal.

Copy to:

1. Regional Officer, MPCB, Amravati and Sub-Regional Officer, MPCB, Amravati I
- They are directed to ensure the compliance of the consent conditions.
- They are directed to obtain the BG's as per consent conditions.
2. Chief Accounts Officer, MPCB,Sion, Mumbai
3. CAC desk-for record and website updating purpose.

SCHEDULE-I

Terms & conditions for compliance of Water Pollution Control:

1. A] As per your application, you have provided the Effluent Treatment Plant (ETP) with the design capacity of 1440 m3/day.

B] The Applicant shall operate the effluent treatment plant (ETP) to treat the trade effluent so as to achieve the following standards prescribed by the Board or under EP Act, 1986 and Rules made there under from time to time, whichever is stringent:

Sr.No	Parameters	Limiting concentration not to exceed in mg/l, except for pH
For Condenser Cooling Water		
(1)	pH	Between 6.5 to 8.5
(2)	Temperature	Not to exceed 5°C than that of intake water temp.
(3)	Free available chlorine	Not to exceed 0.5 mg/l
Boiler Blow Down		
(1)	Suspended Solids	Not to exceed 100 mg/l
(2)	Oil & Grease	Not to exceed 10 mg/l
(3)	Copper (Total)	Not to exceed 1 mg/l
(4)	Iron (Total)	Not to exceed 1 mg/l
Cooling Tower Blow Down		
(1)	Free available chlorine	Not to exceed 0.5 mg/l
(2)	Zinc	Not to exceed 1 mg/l
(3)	Chromium (Total)	Not to exceed 0.2 mg/l
(4)	Phosphate	Not to exceed 5 mg/l
D.M. Plant Effluent		
(1)	pH	5.5 to 9
(2)	Suspended Solids	Not to exceed 100 mg/l
(3)	Oil & Grease	Not to exceed 10 mg/l
(4)	BOD 3 days	Not to exceed 30 mg/l
(5)	COD	Not to exceed 250 mg/l
(6)	TDS	Not to exceed 2100 mg/l

C] The Industry shall ensure connectivity online monitoring system to the MPCB server including separate energy meter for pollution control system.

D] The treated effluent shall be Recycle/reused 100 % for Cooling tower, Dust suppression and Ash handling plant etc. after confirming above standards. In no case, effluent shall find its way to outside factory premises.

2. A] As per your application, you have provided Sewage Treatment Plant of designed capacity 385 CMD for the treatment of 380 CMD of sewage.

B] The Applicant shall operate the sewage treatment system to treat the sewage so as to achieve the following standards.

Sr.No	Parameters	Standards (mg/l)	
1	Suspended Solids	Not to exceed	50 mg/l
2	BOD 3 days 27°C	Not to exceed	30 mg/l
3	COD	Not to exceed	100 mg/l

C] The treated sewage shall be recycled for secondary purposes to the maximum extent and remaining shall be discharged on land for gardening within premise after confirming above standards. In no case, sewage shall find its way to outside factory premises.

3. The Board reserves its rights to review plans, specifications or other data relating to plant setup for the treatment of waterworks for the purification there of & the system for the disposal of sewage or trade effluent or in connection with the grant of any consent conditions. The Applicant shall obtain prior consent of the Board to take steps to establish the unit or establish any treatment and disposal system or an extension or addition thereto.

4. The industry shall ensure replacement of pollution control system or its parts after expiry of its expected life as defined by manufacturer so as to ensure the compliance of standards and safety of the operation thereof.

5. The Applicant shall comply with the provisions of the Water (Prevention & Control of Pollution) Act, 1974 and as amended, by installing water meters and other provisions as contained in the said act:

Sr. No.	Purpose for water consumed	Water consumption quantity (CMD)
1.	Industrial Cooling, spraying in mine pits or boiler feed	111292.00
2.	Domestic purpose	623.00
3.	Processing whereby water gets polluted & pollutants are easily biodegradable	1218.00
4.	Processing whereby water gets polluted & pollutants are not easily biodegradable and are toxic	0.00
5.	Gardening	0

6. The Applicant shall provide Specific Water Pollution control system as per the conditions of EP Act, 1986 and rule made there under from time to time/ Environmental Clearance/ CREP guidelines.

7. The industry shall reduce specific water consumption 3.5 m3/MWh as per MoEF&CC notification dtd. 7th Dec 2015 and as amended 28th June, 2018.

SCHEDULE-II

Terms & conditions for compliance of Air Pollution Control:

1. As per your application, you have provided the Air pollution control (APC) system and erected following stack (s) to observe the following fuel pattern:

Stack No.	Source	APC System provided/proposed	Stack Height(in mtr)	Type of Fuel	Sulphur Content(in %)	Pollutant	Standard
S-1 (Bi-Flue stack for Boiler 1 & 2)	Boiler No 1	ESP Stack	275.00	Coal 4118.5 MT/Day	0.48	TPM	50 Mg/Nm^3
						SO2	600 Mg/Nm^3
						NOx	450 Mg/Nm^3
						Mercury	0.03 Mg/Nm^3
S-1 (Bi-Flue stack for Boiler 1 & 2)	Boiler No 2	ESP Stack	275.00	Coal 4118.5 MT/Day	0.48	TPM	50 Mg/Nm^3
						SO2	600 Mg/Nm^3
						NOx	450 Mg/Nm^3
						Mercury	0.03 Mg/Nm^3
S-2 (Tri-Flue stack for Boiler 3,4 & 5)	Boiler No 3	ESP Stack	275.00	Coal 4118.5 MT/Day	0.48	TPM	50 Mg/Nm^3
						SO2	600 Mg/Nm^3
						NOx	450 Mg/Nm^3
						Mercury	0.03 Mg/Nm^3
S-2 (Tri-Flue stack for Boiler 3,4 & 5)	Boiler No 4	ESP Stack	275.00	Coal 4118.5 MT/Day	0.48	TPM	50 Mg/Nm^3
						SO2	600 Mg/Nm^3
						NOx	450 Mg/Nm^3
						Mercury	0.03 Mg/Nm^3
S-2 (Tri-Flue stack for Boiler 3,4 & 5)	Boiler No 5	ESP Stack	275.00	Coal 4118.5 MT/Day	0.48	TPM	50 Mg/Nm^3
						SO2	600 Mg/Nm^3
						NOx	450 Mg/Nm^3
						Mercury	0.03 Mg/Nm^3
S-3	DG Set 1 (1010 KVA)	Acoustic Enclosure Stack	6.50	HSD 2.6 KL/D	0.25	TPM	150 Mg/Nm^3
						SO2	52 Kg/Day
S-4	DG Set 2 (750 KVA)	Acoustic Enclosure Stack	5.50	HSD 2.2 KL/D	0.25	TPM	150 Mg/Nm^3
						SO2	44 Kg/Day
S-5	DG Set 3 (1010 KVA)	Acoustic Enclosure Stack	6.50	HSD 2.6 KL/D	0.25	TPM	150 Mg/Nm^3
						SO2	52 Kg/Day
S-6	DG Set 4 (750 KVA)	Acoustic Enclosure Stack	5.50	HSD 2.2 KL/D	0.25	TPM	150 Mg/Nm^3
						SO2	44 Kg/Day
S-7	DG Set 5 (750 KVA)	Acoustic Enclosure Stack	5.50	HSD 2.2 KL/D	0.25	TPM	150 Mg/Nm^3
						SO2	44 Kg/Day
0	For Boiler Light up	Existing Boiler stack	275.00	LDO 2.6 KL/D	1.5	SO2	93.6 Kg/Day

2. The Applicant shall provide Specific Air Pollution control equipments as per the conditions of EP Act, 1986 and rule made there under from time to time/ Environmental Clearance / CREP guidelines.

3. The applicant shall operate and maintain above mentioned air pollution control system, so as to achieve the level of pollutants to the following standards:

Units	Parameters	Standards
Standards for Thermal Power Plant:		
Unit 1 to 5	**TPPs (Units) installed after 1st January, 2003, upto 31st December, 2016***	
	Particulate Matter	50 mg / Nm^3
	Sulphur Dioxide (SO_2)	600 mg / Nm^3
	Oxides of Nitrogen (NOx)	450 mg / Nm^3
	Mercury (Hg)	0.03 mg / Nm^3

4. The Applicant shall obtain necessary prior permission for providing additional control equipment with necessary specifications and operation thereof or alteration or replacement/alteration well before its life come to an end or erection of new pollution control equipment.
5. The Board reserves its rights to vary all or any of the condition in the consent, if due to any technological improvement or otherwise such variation (including the change of any control equipment, other in whole or in part is necessary).
6. Control Equipment.
   a) Electrostatic Precipitator (ESP) of sufficient capacity shall be provided to Boiler and any other sources of particulate matter and it shall be Operate and maintain so as to ensure that TPM emission doesnot exceed 50 mg/Nm3.
   b) Dust collecting system and automatic water sprinkler system provided to Coal Handling Plants shall be operate and maintain continuously.
   c) Dust collector of sufficient capacity provided to coal crusher and any other source of SPM shall operate and maintain continuously.
   d) There shall not be any fugutive emission from coal storage yard.
   e) The industry shall make necessary provisions for installing FGD with 90% efficiency in its design and layout ad sufficient floor space so that it can be installed in future, as & when directed by Board.

SCHEDULE-III

Details of Bank Guarantees:

Sr. No.	*Consent (C2E/ C2O /C2R)*	*Amt of BG Imposed*	*Submission Period*	*Purpose of BG*	*Compliance Period*	*Validity Date*
1	C2R	Rs. 50.0 Lakh	15 days	Towards Operation and Maintenance of Air Pollution Control Devices to achieve emission standards.	Continuous	30.06.2027
2	C2R	Rs. 5.0 Lakh	15 days	Towards utilization of fly ash as per As per MoEF & CC notification vide S.O. 5481(E) dtd.31.12.2021 & its amendment dtd.30.12.2022 & amendments thereafter & towards Scientific operation of ash pond i.e. uniform distribution of wet slurry in the pond so as to have minimum depth of water	Continuous	30.06.2027
3	C2R	Rs. 1.0 Lakh	15 days	Towards Mitigation of seepages from wet fly ash conveying system	Continuous	30.06.2027

Sr. No.	Consent (C2E/ C2O /C2R)	Amt of BG Imposed	Submission Period	Purpose of BG	Compliance Period	Validity Date
4	C2R	Rs. 2.0 Lakh	15 days	Towards Scientific closure of abandoned ash pond with soil cover and plantation over it & To switch over to 100 % usable dry fly ash collection and storage	Continuous	30.06.2027
5	C2R	Rs. 5.0 Lakh	15 days	Towards Operation & maintenance of the Effluent Treatment Plant to achieve disposal standards	Continuous	30.06.2027

****Existing BG obtained for above purpose if any, may be extended for period of validity as above.**

BG Forfeiture History

Srno.	Consent (C2E/C2O/C2R)	Amount of BG imposed	Submission Period	Purpose of BG	Amount of BG Forfeiture	Reason of BG Forfeiture
NA						

BG Return details

Srno.	Consent (C2E/C2O/C2R)	BG imposed	Purpose of BG	Amount of BG Returned
NA				

SCHEDULE-IV

General Conditions:

1. Conditions for D.G. Set
   a) Noise from the D.G. Set should be controlled by providing an acoustic enclosure or by treating the room acoustically.
   b) Industry should provide acoustic enclosure for control of noise. The acoustic enclosure/ acoustic treatment of the room should be designed for minimum 25 dB (A) insertion loss or for meeting the ambient noise standards, whichever is on higher side. A suitable exhaust muffler with insertion loss of 25 dB (A) shall also be provided. The measurement of insertion loss will be done at different points at 0.5 meters from acoustic enclosure/room and then average.
   c) Industry should make efforts to bring down noise level due to DG set, outside industrial premises, within ambient noise requirements by proper sitting and control measures.
   d) Installation of DG Set must be strictly in compliance with recommendations of DG Set manufacturer.
   e) A proper routine and preventive maintenance procedure for DG set should be set and followed in consultation with the DG manufacturer which would help to prevent noise levels of DG set from deteriorating with use.
   f) D.G. Set shall be operated only in case of power failure.

g) The applicant should not cause any nuisance in the surrounding area due to operation of D.G. Set.

h) The applicant shall comply with the notification of MoEFCC, India on Environment (Protection) second Amendment Rules vide GSR 371(E) dated 17.05.2002 and its amendments regarding noise limit for generator sets run with diesel.

2. The applicant shall maintain good housekeeping.
3. The non-hazardous solid waste arising in the factory premises, sweepings, etc. be disposed of scientifically so as not to cause any nuisance / pollution. The applicant shall take necessary permissions from civic authorities for disposal of solid waste.
4. The applicant shall not change or alter the quantity, quality, the rate of discharge, temperature or the mode of the effluent/emissions or hazardous wastes or control equipments provided for without previous written permission of the Board. The industry will not carry out any activity, for which this consent has not been granted/without prior consent of the Board.
5. The industry shall ensure that fugitive emissions from the activity are controlled so as to maintain clean and safe environment in and around the factory premises.
6. The industry shall submit quarterly statement in respect of industries obligation towards consent and pollution control compliance's duly supported with documentary evidences (format can downloaded from MPCB official site).
7. The industry shall submit official e-mail address and any change will be duly informed to the MPCB.
8. The industry shall achieve the National Ambient Air Quality standards prescribed vide Government of India, Notification No. B-29016/20/90/PCI-L dated. 18.11.2009 as amended.
9. The Board reserves its rights to review plans, specifications or other data relating to plant setup for the treatment of waterworks for the purification thereof & the system for the disposal of sewage or trade effluent or in connection with the grant of any consent conditions. The Applicant shall obtain prior consent of the Board to take steps to establish the unit or establish any treatment and disposal system or an extension or addition thereto.
10. The industry shall ensure replacement of pollution control system or its parts after expiry of its expected life as defined by manufacturer so as to ensure the compliance of standards and safety of the operation thereof.
11. The PP shall provide personal protection equipment as per norms of Factory Act
12. Industry should monitor effluent quality, stack emissions and ambient air quality monthly/quarterly.
13. Whenever due to any accident or other unforeseen act or even, such emissions occur or is apprehended to occur in excess of standards laid down, such information shall be forthwith Reported to Board, concerned Police Station, office of Directorate of Health Services, Department of Explosives, Inspectorate of Factories and Local Body. In case of failure of pollution control equipments, the production process connected to it shall be stopped.
14. The applicant shall provide an alternate electric power source sufficient to operate all pollution control facilities installed to maintain compliance with the terms and conditions of the consent. In the absence, the applicant shall stop, reduce or otherwise, control production to abide by terms and conditions of this consent.
15. The industry shall recycle/reprocess/reuse/recover Hazardous Waste as per the provision contain in the Hazardous and Other Wastes (M & TM) Rules 2016, which can be recycled /processed /reused /recovered and only waste which has to be incinerated shall go to incineration and waste which can be used for land filling and cannot be recycled/reprocessed etc. should go for that purpose, in order to reduce load on incineration and landfill site/environment.
16. An inspection book shall be opened and made available to the Board’s officers during their visit to the applicant.

17. Industry shall strictly comply with the Water (P&CP) Act, 1974, Air (P&CP) Act, 1981 and Environmental Protection Act, 1986 and industry specific standard under EP Rules 1986 which are available on MPCB website (www.mpcb.gov.in).
18. Separate drainage system shall be provided for collection of trade and sewage effluents. Terminal manholes shall be provided at the end of the collection system with arrangement for measuring the flow. No effluent shall be admitted in the pipes/sewers downstream of the terminal manholes. No effluent shall find its way other than in designed and provided collection system.
19. Neither storm water nor discharge from other premises shall be allowed to mix with the effluents from the factory.
20. The industry should not cause any nuisance in surrounding area.
21. The industry shall take adequate measures for control of noise levels from its own sources within the premises so as to maintain ambient air quality standard in respect of noise to less than 75 dB (A) during day time and 70 dB (A) during night time. Day time is reckoned in between 6 a.m. and 10 p.m. and night time is reckoned between 10 p.m. and 6 a.m.
22. The industry shall create the Environmental Cell by appointing an Environmental Engineer, Chemist and Agriculture expert for looking after day to day activities related to Environment and irrigation field where treated effluent is used for irrigation.
23. The applicant shall provide ports in the chimney/(s) and facilities such as ladder, platform etc. for monitoring the air emissions and the same shall be open for inspection to/and for use of the Board's Staff. The chimney(s) vents attached to various sources of emission shall be designated by numbers such as S-1, S-2, etc. and these shall be painted/ displayed to facilitate identification.
24. The industry should comply with the Hazardous and Other Wastes (M & TM) Rules, 2016 and submit the Annual Returns as per Rule 6(5) & 20(2) of Hazardous and Other Wastes (M & TM) Rules, 2016 for the preceding year April to March in Form-IV by 30th June of every year.
25. The applicant shall install a separate meter showing the consumption of energy for operation of domestic and industrial effluent treatment plants and air pollution control system. A register showing consumption of chemicals used for treatment shall be maintained.
26. The applicant shall bring minimum 33% of the available open land under green coverage/ plantation. The applicant shall submit a yearly statement by 30th September every year on available open plot area, number of trees surviving as on 31st March of the year and number of trees planted by September end.
27. The Board reserves its rights to review plans, specifications or other data relating to plant setup for the treatment of waterworks for the purification thereof & the system for the disposal of sewage or trade effluent or in connection with the grant of any consent conditions.
28. The firm shall submit to this office, the 30th day of September every year, the Environment Statement Report for the financial year ending 31st March in the prescribed FORM-V as per the provisions of Rule 14 of the Environment (Protection) (second Amendment) Rules, 1992.
29. The Applicant shall obtain necessary prior permission for providing additional control equipment with necessary specifications and operation thereof or alteration or replacement/alteration well before its life come to an end or erection of new pollution control equipment.

30. The Board reserves its rights to vary all or any of the condition in the consent, if due to any technological improvement or otherwise such variation (including the change of any control equipment, other in whole or in part is necessary).
31. The applicant shall provide facility for collection of environmental samples and samples of trade and sewage effluents, air emissions and hazardous waste to the Board staff at the terminal or designated points and shall pay to the Board for the services rendered in this behalf.

This certificate is digitally & electronically signed.
